



**STATE OF TENNESSEE
DEPARTMENT OF HEALTH
ENVIRONMENTAL LABORATORIES**

TDH: Lab Services JRL
Lab Services - Jackson Regional Lab
Jackson, TN 38301
731-426-0686

TDH: Lab Services KRL
Lab Services - Knoxville Regional Lab
Knoxville, TN 37920
865-549-5201

TDH: Lab Services NCL
Lab Services - Nashville Central Lab
Nashville, TN 37243
615-262-6300


Sent To: Steve Roberts
TDEC-DWS
Knoxville FO
3711 Middlebrook Pike
Knoxville, TN 37921

Lab ID: K00004014
Knoxville Regional Laboratory

Sampling Agency: TDEC: Division of Water Supply

Billing Code: 327.39-12

This is to certify that the following results were determined using good laboratory practices and in accordance with federal or state approved methodologies.



Analytical Supervisor

Lab-Sample Number: K00004014001
 Project Name:
 Sample Description: Kingston WTP

Field Determinations

pH:
 Chlorine, residual:
 Conductivity:
 Temperature:
 Dissolved Oxygen:
 Other:
 Flow: CFS

Sampler Project Name: Raw
 Project Site No.:
 Station No.:
 Date/Time Collected: 08/09/2010 08:25
 Sampler's Name: Geoff Klein
 County: ROANE - 73
 Sample Matrix: Water
 EFO: Knoxville
 Sampling Agency: TDEC-DWS
 Billing Code: 327.39-12
 Send Report To: TDEC-DWS
 Priority Date: 08/19/2010
 Date/Time Received: 08/09/2010 12:58

Agency Invoiced: TDEC-DWS
 Received By: E McCrary

TEST: Digestion Metals		METHOD: EPA 200.2				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Digestion Metals	08/10/2010				A Wilson	8/10/2010

TEST: ICP-MS		METHOD: EPA 200.8				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Arsenic	U	µg/L	0.82	5	M Pattanayek	8/10/2010
Barium	28	µg/L	0.26	5	M Pattanayek	8/10/2010
Beryllium	U	µg/L	0.21	1	M Pattanayek	8/10/2010
Cadmium	U	µg/L	0.5	1	M Pattanayek	8/10/2010
Chromium	U	µg/L	0.89	5	M Pattanayek	8/10/2010
Cobalt	U	µg/L	0.36	1	M Pattanayek	8/10/2010
Lead	U	µg/L	0.51	1	M Pattanayek	8/10/2010
Manganese	20	µg/L	0.59	1	M Pattanayek	8/10/2010
Selenium	U	µg/L	1.9	5	M Pattanayek	8/10/2010
Thallium	U	µg/L	0.25	1	M Pattanayek	8/10/2010
Vanadium	U	µg/L	2	5	M Pattanayek	8/10/2010

TEST: Mercury		METHOD: EPA 245.1				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Mercury	U	µg/L	0.038	0.2	A Bass	8/10/2010

J - Estimated value between MDL and MQL
 MDL - Method Detection Limit
 MQL - Method Quantitation Limit
 U - Undetected

Lab-Sample Number: K00004014002
 Project Name:
 Sample Description: Kingston WTP

Field Determinations

pH:
 Chlorine, residual:
 Conductivity:
 Temperature:
 Dissolved Oxygen:
 Other:
 Flow: CFS

Sampler Project Name: Finish
 Project Site No.:
 Station No.:
 Date/Time Collected: 08/09/2010 08:30
 Sampler's Name: Geoff Klein
 County: ROANE - 73
 Sample Matrix: Water
 EFO: Knoxville
 Sampling Agency: TDEC-DWS
 Billing Code: 327.39-12
 Send Report To: TDEC-DWS
 Priority Date: 08/19/2010
 Date/Time Received: 08/09/2010 12:58

Agency Invoiced: TDEC-DWS

Received By: E McCrary

TEST: Digestion Metals		METHOD: EPA 200.2				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Digestion Metals					A Wilson	8/10/2010

TEST: ICP-MS		METHOD: EPA 200.8				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Arsenic	U	µg/L	0.82	5	M Pattanayek	8/10/2010
Barium	21	µg/L	0.26	5	M Pattanayek	8/10/2010
Beryllium	U	µg/L	0.21	1	M Pattanayek	8/10/2010
Cadmium	U	µg/L	0.5	1	M Pattanayek	8/10/2010
Chromium	U	µg/L	0.89	5	M Pattanayek	8/10/2010
Cobalt	U	µg/L	0.36	1	M Pattanayek	8/10/2010
Lead	U	µg/L	0.51	1	M Pattanayek	8/10/2010
Manganese	U	µg/L	0.59	1	M Pattanayek	8/10/2010
Selenium	U	µg/L	1.9	5	M Pattanayek	8/10/2010
Thallium	U	µg/L	0.25	1	M Pattanayek	8/10/2010
Vanadium	U	µg/L	2	5	M Pattanayek	8/10/2010

TEST: Mercury		METHOD: EPA 245.1				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Mercury	U	µg/L	0.038	0.2	A Bass	8/10/2010

J - Estimated value between MDL and MQL
 MDL - Method Detection Limit
 MQL - Method Quantitation Limit
 U - Undetected

Lab-Sample Number: K00004014003
 Project Name:
 Sample Description: Rockwood WTP

Field Determinations
 pH:
 Chlorine, residual:
 Conductivity:
 Temperature:
 Dissolved Oxygen:
 Other:
 Flow: CFS

Sampler Project Name: Raw
 Project Site No.:
 Station No.:
 Date/Time Collected: 08/09/2010 09:10
 Sampler's Name: Geoff Klein
 County: ROANE - 73
 Sample Matrix: Water
 EFO: Knoxville
 Sampling Agency: TDEC-DWS
 Billing Code: 327.39-12
 Send Report To: TDEC-DWS
 Priority Date: 08/19/2010
 Date/Time Received: 08/09/2010 12:58

Agency Invoiced: TDEC-DWS
 Received By: E McCrary

TEST: Digestion Metals		METHOD: EPA 200.2					
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE	
Digestion Metals	08/10/2010				A Wilson	8/10/2010	

TEST: ICP-MS		METHOD: EPA 200.8					
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE	
Arsenic	1.3J	µg/L	0.82	5	M Pattanayek	8/10/2010	
Barium	30	µg/L	0.26	5	M Pattanayek	8/10/2010	
Beryllium	U	µg/L	0.21	1	M Pattanayek	8/10/2010	
Cadmium	U	µg/L	0.5	1	M Pattanayek	8/10/2010	
Chromium	U	µg/L	0.89	5	M Pattanayek	8/10/2010	
Cobalt	U	µg/L	0.36	1	M Pattanayek	8/10/2010	
Lead	0.71J	µg/L	0.51	1	M Pattanayek	8/10/2010	
Manganese	16	µg/L	0.59	1	M Pattanayek	8/10/2010	
Selenium	U	µg/L	1.9	5	M Pattanayek	8/10/2010	
Thallium	U	µg/L	0.25	1	M Pattanayek	8/10/2010	
Vanadium	U	µg/L	2	5	M Pattanayek	8/10/2010	

TEST: Mercury		METHOD: EPA 245.1					
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE	
Mercury	U	µg/L	0.038	0.2	A Bass	8/10/2010	

J - Estimated value between MDL and MQL
 MDL - Method Detection Limit
 MQL - Method Quantitation Limit
 U - Undetected

Lab-Sample Number: K00004014004
 Project Name:
 Sample Description: Rockwood WTP

Field Determinations
 pH:
 Chlorine, residual:
 Conductivity:
 Temperature:
 Dissolved Oxygen:
 Other:
 Flow: CFS

Sampler Project Name: Finish
 Project Site No.:
 Station No.:
 Date/Time Collected: 08/09/2010 09:15
 Sampler's Name: Geoff Klein
 County: ROANE - 73
 Sample Matrix: Water
 EFO: Knoxville
 Sampling Agency: TDEC-DWS
 Billing Code: 327.39-12
 Send Report To: TDEC-DWS
 Priority Date: 08/19/2010
 Date/Time Received: 08/09/2010 12:58

Agency Invoiced: TDEC-DWS
 Received By: E McCrary

TEST: Digestion Metals		METHOD: EPA 200.2					
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE	
Digestion Metals	08/10/2010				A Wilson	8/10/2010	

TEST: ICP-MS		METHOD: EPA 200.8					
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE	
Arsenic	U	µg/L	0.82	5	M Pattanayek	8/10/2010	
Barium	27	µg/L	0.26	5	M Pattanayek	8/10/2010	
Beryllium	U	µg/L	0.21	1	M Pattanayek	8/10/2010	
Cadmium	U	µg/L	0.5	1	M Pattanayek	8/10/2010	
Chromium	0.99J	µg/L	0.89	5	M Pattanayek	8/10/2010	
Cobalt	U	µg/L	0.36	1	M Pattanayek	8/10/2010	
Lead	U	µg/L	0.51	1	M Pattanayek	8/10/2010	
Manganese	0.76J	µg/L	0.59	1	M Pattanayek	8/10/2010	
Selenium	U	µg/L	1.9	5	M Pattanayek	8/10/2010	
Thallium	U	µg/L	0.25	1	M Pattanayek	8/10/2010	
Vanadium	U	µg/L	2	5	M Pattanayek	8/10/2010	

TEST: Mercury		METHOD: EPA 245.1					
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE	
Mercury	U	µg/L	0.038	0.2	A Bass	8/10/2010	

J - Estimated value between MDL and MQL
 MDL - Method Detection Limit
 MQL - Method Quantitation Limit
 U - Undetected



**STATE OF TENNESSEE
DEPARTMENT OF HEALTH
ENVIRONMENTAL LABORATORIES**

TDH: Lab Services JRL
Lab Services - Jackson Regional Lab
Jackson, TN 38301
731-426-0686

TDH: Lab Services KRL
Lab Services - Knoxville Regional Lab
Knoxville, TN 37920
865-549-5201

TDH: Lab Services NCL
Lab Services - Nashville Central Lab
Nashville, TN 37243
615-262-6300


Sent To: Steve Roberts
TDEC-DWS
Knoxville FO
3711 Middlebrook Pike
Knoxville, TN 37921

Lab ID: K00004014
Knoxville Regional Laboratory

Sampling Agency: TDEC: Division of Water Supply

Billing Code: 327.39-12

This is to certify that the following results were determined using good laboratory practices and in accordance with federal or state approved methodologies.


Analytical Supervisor

Lab-Sample Number: K00004014001
Project Name:
Sample Description: Kingston WTP

Field Determinations
pH:
Chlorine, residual:
Conductivity:
Temperature:
Dissolved Oxygen:
Other:
Flow: CFS

Sampler Project Name: Raw
Project Site No.:
Station No.:
Date/Time Collected: 08/09/2010 08:25
Sampler's Name: Geoff Klein
County: ROANE - 73
Sample Matrix: Water
EFO: Knoxville
Sampling Agency: TDEC-DWS
Billing Code: 327.39-12
Send Report To: TDEC-DWS
Priority Date: 08/19/2010
Date/Time Received: 08/09/2010 12:58

Agency Invoiced: TDEC-DWS
Received By: E McCrary

TEST: Alkalinity, Total		METHOD: EPA 310.2				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Total Alkalinity	65	mg/L	3.8	10	S Burchfield	8/11/2010

TEST: Hardness, Calcium		METHOD: SM 3500-Ca D				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Calcium hardness	52	mg/L	0.7	1	M Chen	8/10/2010

J - Estimated value between MDL and MQL
MDL - Method Detection Limit
MQL - Method Quantitation Limit
U - Undetected

Lab-Sample Number: K00004014002
Project Name:
Sample Description: Kingston WTP

Field Determinations
pH:
Chlorine, residual:
Conductivity:
Temperature:
Dissolved Oxygen:
Other:
Flow: CFS

Sampler Project Name: Finish
Project Site No.:
Station No.:
Date/Time Collected: 08/09/2010 08:30
Sampler's Name: Geoff Klein
County: ROANE - 73
Sample Matrix: Water
EFO: Knoxville
Sampling Agency: TDEC-DWS
Billing Code: 327.39-12
Send Report To: TDEC-DWS
Priority Date: 08/19/2010
Date/Time Received: 08/09/2010 12:58

Agency Invoiced: TDEC-DWS
Received By: E McCrary

TEST: Alkalinity, Total		METHOD: EPA 310.2				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Total Alkalinity	61	mg/L	3.8	10	S Burchfield	8/11/2010

TEST: Hardness, Calcium		METHOD: SM 3500-Ca D				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Calcium hardness	49	mg/L	0.7	1	M Chen	8/10/2010

J - Estimated value between MDL and MQL
MDL - Method Detection Limit
MQL - Method Quantitation Limit
U - Undetected

Lab-Sample Number: K00004014003
Project Name:
Sample Description: Rockwood WTP

Field Determinations
pH:
Chlorine, residual:
Conductivity:
Temperature:
Dissolved Oxygen:
Other:
Flow: CFS

Sampler Project Name: Raw
Project Site No.:
Station No.:
Date/Time Collected: 08/09/2010 09:10
Sampler's Name: Geoff Klein
County: ROANE - 73
Sample Matrix: Water
EFO: Knoxville
Sampling Agency: TDEC-DWS
Billing Code: 327.39-12
Send Report To: TDEC-DWS
Priority Date: 08/19/2010
Date/Time Received: 08/09/2010 12:58

Agency Invoiced: TDEC-DWS
Received By: E McCrary

TEST: Alkalinity, Total		METHOD: EPA 310.2				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Total Alkalinity	80	mg/L	3.8	10	S Burchfield	8/11/2010

TEST: Hardness, Calcium		METHOD: SM 3500-Ca D				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Calcium hardness	55	mg/L	0.7	1	M Chen	8/10/2010

J - Estimated value between MDL and MQL
MDL - Method Detection Limit
MQL - Method Quantitation Limit
U - Undetected

Lab-Sample Number: K00004014004
Project Name:
Sample Description: Rockwood WTP

Field Determinations
pH:
Chlorine, residual:
Conductivity:
Temperature:
Dissolved Oxygen:
Other:
Flow: CFS

Sampler Project Name: Finish
Project Site No.:
Station No.:
Date/Time Collected: 08/09/2010 09:15
Sampler's Name: Geoff Klein
County: ROANE - 73
Sample Matrix: Water
EFO: Knoxville
Sampling Agency: TDEC-DWS
Billing Code: 327.39-12
Send Report To: TDEC-DWS
Priority Date: 08/19/2010
Date/Time Received: 08/09/2010 12:58

Agency Invoiced: TDEC-DWS
Received By: E McCrary

TEST: Alkalinity, Total		METHOD: EPA 310.2				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Total Alkalinity	70	mg/L	3.8	10	S Burchfield	8/11/2010

TEST: Hardness, Calcium		METHOD: SM 3500-Ca D				
ANALYTE	RESULT	UNITS	MDL	MQL	ANALYZED BY:	DATE
Calcium hardness	56	mg/L	0.7	1	M Chen	8/10/2010

J - Estimated value between MDL and MQL
MDL - Method Detection Limit
MQL - Method Quantitation Limit
U - Undetected