

**Microbac**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

**CERTIFICATE OF ANALYSIS**  
**PRELIMINARY REPORT**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/26/2009  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/26/2009  
 Permit No.

Work Order Number: 0903-01037

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech	
<b>001 RAW 3/26/09 0630</b>							
[ TAL METALS ]						00:00	JKD
ALUMINUM	EPA 200.7	0.152 MG/L	N	03/30/2009	21:21	JKD	
ANTIMONY	EPA 200.8	<0.005 MG/L		04/01/2009	12:30	MCD	
ARSENIC	EPA 200.8	<0.005 MG/L		04/01/2009	12:30	MCD	
BARIUM	EPA 200.7	0.0216 MG/L		03/30/2009	21:21	JKD	
BERYLLIUM	EPA 200.7	<0.00050 MG/L		03/30/2009	21:21	JKD	
CADMIUM	EPA 200.7	<0.00050 MG/L	N	03/30/2009	21:21	JKD	
CHROMIUM	EPA 200.7	<0.00050 MG/L	N	03/30/2009	21:21	JKD	
COBALT	EPA 200.7	<0.00050 MG/L		03/30/2009	21:21	JKD	
COPPER	EPA 200.7	0.0024 MG/L	E	03/30/2009	21:21	JKD	
IRON	EPA 200.7	0.156 MG/L		03/30/2009	21:21	JKD	
LEAD	EPA 200.8	<0.005 MG/L		04/01/2009	12:30	MCD	
MAGNESIUM	EPA 200.7	5.31 MG/L	J+	03/28/2009	18:25	JKD	
MANGANESE	EPA 200.7	0.0321 MG/L		03/30/2009	21:21	JKD	
MOLYBDENUM	EPA 200.7	<0.00050 MG/L		03/30/2009	21:21	JKD	
MERCURY	EPA 245.1	<0.0002 MG/L		03/30/2009	12:25	LL	
NICKEL	EPA 200.7	<0.00050 MG/L	N	03/30/2009	21:21	JKD	
SELENIUM	EPA 200.8	<0.005 MG/L		04/01/2009	12:30	MCD	
SILVER	EPA 200.7	<0.00050 MG/L		03/30/2009	21:21	JKD	
TIN	EPA 200.7	<0.00050 MG/L		03/30/2009	21:21	JKD	
TITANIUM	EPA 200.7	0.0038 MG/L		03/30/2009	21:21	JKD	
THALLIUM	EPA 200.8	<0.002 MG/L		04/01/2009	12:30	MCD	
ZINC	EPA 200.7	0.0173 MG/L	E	03/30/2009	21:21	JKD	
BORON	EPA 200.7	0.0108 MG/L		03/30/2009	21:21	JKD	
SOLIDS, TOTAL SUSPENDED	SM 2540.D.	5.50 MG/L		03/26/2009	09:45	KDW	
HARDNESS, TOTAL AS CaCO3	EPA 200.7;2340.B.	74.9 MG/L	J+	03/28/2009	18:25	JKD	

**Microbac**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

**CERTIFICATE OF ANALYSIS**  
**PRELIMINARY REPORT**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/26/2009  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/26/2009  
 Permit No.

Work Order Number: 0903-01037

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

**002 RAW 3/26/09 0630 DISSOLVED METALS**

Test	Method	Result	Qual	Date	Time	Tech
[ TAL METALS ]					00:00	
ALUMINUM	EPA 200.7	0.0079 MG/L	N	03/30/2009	20:55	JKD
ANTIMONY	EPA 200.8	<0.005 MG/L		04/01/2009	12:34	MCD
ARSENIC	EPA 200.8	<0.005 MG/L		04/01/2009	12:34	MCD
BARIUM	EPA 200.7	0.0210 MG/L		03/30/2009	20:55	JKD
BERYLLIUM	EPA 200.7	<0.00050 MG/L		03/30/2009	20:55	JKD
CADMIUM	EPA 200.7	<0.00050 MG/L	N	03/30/2009	20:55	JKD
CHROMIUM	EPA 200.7	<0.00050 MG/L	N	03/30/2009	20:55	JKD
COBALT	EPA 200.7	<0.00050 MG/L		03/30/2009	20:55	JKD
COPPER	EPA 200.7	0.0022 MG/L	E	03/30/2009	20:55	JKD
IRON	EPA 200.7	0.0045 MG/L		03/30/2009	20:55	JKD
LEAD	EPA 200.8	<0.005 MG/L		04/01/2009	12:34	MCD
MAGNESIUM	EPA 200.7	5.15 MG/L	J+	03/28/2009	18:32	JKD
MANGANESE	EPA 200.7	<0.0025 MG/L		03/30/2009	20:55	JKD
MOLYBDENUM	EPA 200.7	<0.00050 MG/L		03/30/2009	20:55	JKD
MERCURY	EPA 245.1	<0.0002 MG/L		03/27/2009	18:14	MAR
NICKEL	EPA 200.7	<0.00050 MG/L	N	03/30/2009	20:55	JKD
SELENIUM	EPA 200.8	<0.005 MG/L		04/01/2009	12:34	MCD
SILVER	EPA 200.7	<0.00050 MG/L		03/30/2009	20:55	JKD
TIN	EPA 200.7	<0.00050 MG/L		03/30/2009	20:55	JKD
TITANIUM	EPA 200.7	<0.00050 MG/L		03/30/2009	20:55	JKD
THALLIUM	EPA 200.8	<0.002 MG/L		04/01/2009	12:34	MCD
ZINC	EPA 200.7	0.0362 MG/L	E	03/30/2009	20:55	JKD
BORON	EPA 200.7	0.0120 MG/L		03/30/2009	20:55	JKD
SILICA (SiO2)	EPA 200.7	4.07 MG/L	J+	03/28/2009	18:32	JKD

**Microbac**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

**CERTIFICATE OF ANALYSIS**  
**PRELIMINARY REPORT**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/26/2009  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/26/2009  
 Permit No.

Work Order Number: 0903-01037

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

003 **FINISHED 3/26/09 0630**

[ TAL METALS ]

ALUMINUM	EPA 200.7	0.0855 MG/L	N	03/30/2009	21:28	JKD
ANTIMONY	EPA 200.8	<0.005 MG/L		04/01/2009	12:39	MCD
ARSENIC	EPA 200.8	<0.005 MG/L		04/01/2009	12:39	MCD
BARIUM	EPA 200.7	0.0212 MG/L		03/30/2009	21:28	JKD
BERYLLIUM	EPA 200.7	<0.00050 MG/L		03/30/2009	21:28	JKD
CADMIUM	EPA 200.7	<0.00050 MG/L	N	03/30/2009	21:28	JKD
CHROMIUM	EPA 200.7	<0.00050 MG/L	N	03/30/2009	21:28	JKD
COBALT	EPA 200.7	<0.00050 MG/L		03/30/2009	21:28	JKD
COPPER	EPA 200.7	0.0026 MG/L	E	03/30/2009	21:28	JKD
IRON	EPA 200.7	<0.0030 MG/L		03/30/2009	21:28	JKD
LEAD	EPA 200.8	<0.005 MG/L		04/01/2009	12:39	MCD
MAGNESIUM	EPA 200.7	5.55 MG/L	J+	03/28/2009	18:38	JKD
MANGANESE	EPA 200.7	<0.0025 MG/L		03/30/2009	21:28	JKD
MOLYBDENUM	EPA 200.7	<0.00050 MG/L		03/30/2009	21:28	JKD
MERCURY	EPA 245.1	<0.0002 MG/L		03/27/2009	18:16	MAR
NICKEL	EPA 200.7	<0.00050 MG/L	N	03/30/2009	21:28	JKD
SELENIUM	EPA 200.8	<0.005 MG/L		04/01/2009	12:39	MCD
SILVER	EPA 200.7	<0.00050 MG/L		03/30/2009	21:28	JKD
TIN	EPA 200.7	<0.00050 MG/L		03/30/2009	21:28	JKD
TITANIUM	EPA 200.7	<0.00050 MG/L		03/30/2009	21:28	JKD
THALLIUM	EPA 200.8	<0.002 MG/L		04/01/2009	12:39	MCD
ZINC	EPA 200.7	0.0179 MG/L	E	03/30/2009	21:28	JKD
BORON	EPA 200.7	0.0108 MG/L		03/30/2009	21:28	JKD
SOLIDS, TOTAL SUSPENDED	SM 2540,D.	<1.00 MG/L		03/26/2009	09:45	KDW

**Microbac**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

**CERTIFICATE OF ANALYSIS**  
**PRELIMINARY REPORT**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/26/2009  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/26/2009  
 Permit No.

Work Order Number: 0903-01037

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

003 **FINISHED 3/26/09 0630**

.....continued

HARDNESS, TOTAL AS CaCO3	EPA 200.7;2340,B.	78.2 MG/L	J+	03/28/2009	18:38	JKD
--------------------------	-------------------	-----------	----	------------	-------	-----

004 **FINISHED 3/26/09 0630 DISSOLVED METALS**

Test	Method	Result	Qual	Date	Time	Tech
[ TAL METALS ]					00:00	
ALUMINUM	EPA 200.7	0.0872 MG/L	N	03/30/2009	21:02	JKD
ANTIMONY	EPA 200.8	<0.005 MG/L		04/01/2009	12:43	MCD
ARSENIC	EPA 200.8	<0.005 MG/L		04/01/2009	12:43	MCD
BARIUM	EPA 200.7	0.0211 MG/L		03/30/2009	21:02	JKD
BERYLLIUM	EPA 200.7	<0.00050 MG/L		03/30/2009	21:02	JKD
CADMIUM	EPA 200.7	<0.00050 MG/L	N	03/30/2009	21:02	JKD
CHROMIUM	EPA 200.7	<0.00050 MG/L	N	03/30/2009	21:02	JKD
COBALT	EPA 200.7	<0.00050 MG/L		03/30/2009	21:02	JKD
COPPER	EPA 200.7	0.0028 MG/L	E	03/30/2009	21:02	JKD
IRON	EPA 200.7	<0.0030 MG/L		03/30/2009	21:02	JKD
LEAD	EPA 200.8	<0.005 MG/L		04/01/2009	12:43	MCD
MAGNESIUM	EPA 200.7	5.62 MG/L	J+	03/28/2009	19:10	JKD
MANGANESE	EPA 200.7	<0.0025 MG/L		03/30/2009	21:02	JKD
MOLYBDENUM	EPA 200.7	<0.00050 MG/L		03/30/2009	21:02	JKD
MERCURY	EPA 245.1	<0.0002 MG/L		03/27/2009	18:25	MAR
NICKEL	EPA 200.7	<0.00050 MG/L	N	03/30/2009	21:02	JKD
SELENIUM	EPA 200.8	<0.005 MG/L		04/01/2009	12:43	MCD
SILVER	EPA 200.7	<0.00050 MG/L		03/30/2009	21:02	JKD
TIN	EPA 200.7	<0.00050 MG/L		03/30/2009	21:02	JKD
TITANIUM	EPA 200.7	<0.00050 MG/L		03/30/2009	21:02	JKD

® **Microbac Laboratories, Inc.**

**Microbac**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

**CERTIFICATE OF ANALYSIS**  
**PRELIMINARY REPORT**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/26/2009  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/26/2009  
 Permit No.

Work Order Number: 0903-01037

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

004 **FINISHED 3/26/09 0630 DISSOLVED METALS**

.....continued

THALLIUM	EPA 200.8	<0.002 MG/L		04/01/2009	12:43	MCD
ZINC	EPA 200.7	0.0027 MG/L	E	03/30/2009	21:02	JKD
BORON	EPA 200.7	0.0112 MG/L		03/30/2009	21:02	JKD
SILICA (SiO2)	EPA 200.7	4.24 MG/L	J+	03/28/2009	19:10	JKD

**REVISED REPORT TO CONTAIN BACK-UP STATE CERTIFIED DATA FOR SB, AS, PB, SE AND TL. ANALYSIS SUBCONTRACTED TO MICROBAC LABORATORIES CHICAGOLAND DIVISION (TN LAB ID#04017). JN 4-2-09.**

RESPECTFULLY SUBMITTED: \_\_\_\_\_

MICROBAC LABORATORIES, INC.

*Thank you for your business. We invite your feedback on our level of service to you. Please contact the Laboratory Director, James Nokes, at 865-977-1200, the COO, Robert Morgan, at rmorgan@microbac.com or the CEO, Trevor Boyce, at tboyce@microbac.com with any comments or suggestions.*

® **Microbac Laboratories, Inc.**

**Microbac**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.

TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

**CERTIFICATE OF ANALYSIS**  
**PRELIMINARY REPORT**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/26/2009  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/26/2009  
 Permit No.

Work Order Number: 0903-01037

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

As regulatory limits change frequently, Microbac advises the recipient of this report to confirm such limits with the appropriate Federal, state, or local authorities before acting in reliance on the regulatory limits provided.

Microbac Laboratories, Inc. cannot guarantee the confidentiality of any facsimile or e-mail transmittal. The information in this communication is intended for the exclusive use of the addressee. If you are not the intended recipient, you are notified that any disclosure, copying, distributing, or the taking of any action in reliance on the contents of this information is strictly prohibited. If you received this transmission in error, please notify us immediately.

**QUALIFIER DEFINITIONS:**

- B = Detected in the associated Method Blank
- C = As Tons CaCO<sub>3</sub>, equivalent per 1,000 tons material
- D = Surrogate recoveries not calculated due to matrix interference and resulting sample dilution
- E1 = Elevated detection limits due to sample matrix interference
- E2 = Elevated detection limits due to high analyte concentration
- H = Analyte was prepared and/or analyzed outside of the analytical method holding time
- I = Spike recovery outside control limits due to sample matrix interference or high analyte concentration
- J = The result is an estimated quantity. The associated numerical value is the approximate concentration of the analyte in the sample
- J+ = The result is an estimated quantity, but the result may be biased high
- J- = The result is an estimated quantity, but the result may be biased low
- UJ = The analyte was analyzed for, but was not detected. The reported quantitation limit is approximate and may be inaccurate or imprecise
- K = Analyte concentration estimated due to sample matrix interference and/or high analyte concentration interference
- L1 = Liquid portion of dual phase sample analyzed only
- L2 = Solid portion of dual phase sample analyzed only
- M = Miscellaneous (see entry below analytical results)
- N = Analyte acceptable but matrix spike/matrix spike duplicate outside accepted recovery criteria
- \* = Matrix Spike/Matrix Spike Duplicate RPD is outside acceptable limits
- P = Sample received improperly preserved
- R = Relative Percent Duplicate (RPD) outside accepted recovery limits
- S1 = Spike recovery outside recovery limits
- S2 = Surrogate recovery outside of control limits. The data was accepted based on the valid recovery of remaining surrogate.
- U = Undetected
- V = Elevated reporting limits due to insufficient sample volume
- W = Results reports on dry weight basis

**ABBREVIATIONS:**

- TNTC = Too Numerous To Count
- UG/L = Micrograms per Liter (PPB)
- UG/KG = Micrograms per Kilogram (PPB)
- MG/L = Milligrams per Liter (PPM)
- MG/KG = Milligrams per Kilogram (PPM)
- CFU = Colony Forming Unit
- ND = Not Detected at or below the reporting limit
- TIC = Tentatively Identified Compound





® **Microbac Laboratories, Inc.**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
<http://www.microbac.com>  
 E-Mail: [knoxville@microbac.com](mailto:knoxville@microbac.com)

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

# PRELIMINARY REPORT

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/26/2009  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/26/2009  
 Permit No.

Work Order Number: 0903-01037

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------