

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 4/25/2009
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 4/25/2009
 Permit No. 0000360

Work Order Number: 0904-01088

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
001 RAW 4/25/09 0630						
[TAL METALS]						
ALUMINUM	EPA 200.7	<0.0050 MG/L	N,*	04/28/2009	13:34	JKD
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	04/28/2009	13:34	JKD
ARSENIC	EPA 200.7	<0.0010 MG/L	M	04/28/2009	13:34	JKD
BARIUM	EPA 200.7	0.0173 MG/L		04/28/2009	13:34	JKD
BERYLLIUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:34	JKD
CADMIUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:34	JKD
CHROMIUM	EPA 200.7	<0.0010 MG/L	N	04/28/2009	13:34	JKD
COBALT	EPA 200.7	<0.0010 MG/L		04/28/2009	13:34	JKD
COPPER	EPA 200.7	0.0016 MG/L		04/28/2009	13:34	JKD
IRON	EPA 200.7	0.0626 MG/L		04/28/2009	13:34	JKD
LEAD	EPA 200.7	<0.0010 MG/L	M	04/28/2009	13:34	JKD
MAGNESIUM	EPA 200.7	4.17 MG/L	J+,E	04/27/2009	15:26	JKD
MANGANESE	EPA 200.7	0.0123 MG/L		04/28/2009	13:34	JKD
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:34	JKD
MERCURY	EPA 245.1	<0.0002 MG/L		04/27/2009	11:32	MAR
NICKEL	EPA 200.7	<0.0010 MG/L	N	04/28/2009	13:34	JKD
SELENIUM	EPA 200.7	<0.0020 MG/L	M	04/28/2009	13:34	JKD
SILVER	EPA 200.7	<0.0010 MG/L		04/28/2009	13:34	JKD
TIN	EPA 200.7	<0.0010 MG/L		04/28/2009	13:34	JKD
TITANIUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:34	JKD
THALLIUM	EPA 200.7	<0.0020 MG/L	M	04/28/2009	13:34	JKD
ZINC	EPA 200.7	0.0063 MG/L		04/28/2009	13:34	JKD
BORON	EPA 200.7	0.0049 MG/L	N	04/28/2009	13:34	JKD
SOLIDS, TOTAL SUSPENDED	SM 2540,D.	5.20 MG/L		04/27/2009	11:00	KDW
HARDNESS, TOTAL AS CaCO3	EPA 200.7;2340,B.	62.5 MG/L	J+	04/27/2009	15:26	JKD

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 4/25/2009
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 4/25/2009
 Permit No. 0000360

Work Order Number: 0904-01088

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

002 RAW 4/25/09 0630 DISSOLVED METALS

Test	Method	Result	Qual	Date	Time	Tech
[TAL METALS]					00:00	
ALUMINUM	EPA 200.7	0.0336 MG/L	N,*	04/28/2009	13:40	JKD
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	04/28/2009	13:40	JKD
ARSENIC	EPA 200.7	<0.0010 MG/L	M	04/28/2009	13:40	JKD
BARIUM	EPA 200.7	0.0160 MG/L		04/28/2009	13:40	JKD
BERYLLIUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:40	JKD
CADMIUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:40	JKD
CHROMIUM	EPA 200.7	<0.0010 MG/L	N	04/28/2009	13:40	JKD
COBALT	EPA 200.7	<0.0010 MG/L		04/28/2009	13:40	JKD
COPPER	EPA 200.7	0.0011 MG/L		04/28/2009	13:40	JKD
IRON	EPA 200.7	<0.0060 MG/L		04/28/2009	13:40	JKD
LEAD	EPA 200.7	<0.0010 MG/L	M	04/28/2009	13:40	JKD
MAGNESIUM	EPA 200.7	3.83 MG/L	J+,E	04/27/2009	16:38	JKD
MANGANESE	EPA 200.7	<0.0050 MG/L		04/28/2009	13:40	JKD
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:40	JKD
MERCURY	EPA 245.1	<0.0002 MG/L		04/27/2009	11:51	MAR
NICKEL	EPA 200.7	<0.0010 MG/L	N	04/28/2009	13:40	JKD
SELENIUM	EPA 200.7	<0.0020 MG/L	M	04/28/2009	13:40	JKD
SILVER	EPA 200.7	<0.0010 MG/L		04/28/2009	13:40	JKD
TIN	EPA 200.7	<0.0010 MG/L		04/28/2009	13:40	JKD
TITANIUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:40	JKD
THALLIUM	EPA 200.7	<0.0020 MG/L	M	04/28/2009	13:40	JKD
ZINC	EPA 200.7	0.0026 MG/L		04/28/2009	13:40	JKD
BORON	EPA 200.7	0.0046 MG/L	N	04/28/2009	13:40	JKD
SILICA (SiO2)	EPA 200.7	1.53 MG/L		04/27/2009	16:38	JKD

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 4/25/2009
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 4/25/2009
 Permit No. 0000360

Work Order Number: 0904-01088

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

003 **FINISHED 4/25/09 0630**

[TAL METALS]

Test	Method	Result	Qual	Date	Time	Tech
ALUMINUM	EPA 200.7	0.128 MG/L	N,*	04/28/2009	13:47	JKD
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	04/28/2009	13:47	JKD
ARSENIC	EPA 200.7	<0.0010 MG/L	M	04/28/2009	13:47	JKD
BARIUM	EPA 200.7	0.0166 MG/L		04/28/2009	13:47	JKD
BERYLLIUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:47	JKD
CADMIUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:47	JKD
CHROMIUM	EPA 200.7	<0.0010 MG/L	N	04/28/2009	13:47	JKD
COBALT	EPA 200.7	<0.0010 MG/L		04/28/2009	13:47	JKD
COPPER	EPA 200.7	0.0017 MG/L		04/28/2009	13:47	JKD
IRON	EPA 200.7	0.0060 MG/L		04/28/2009	13:47	JKD
LEAD	EPA 200.7	<0.0010 MG/L	M	04/28/2009	13:47	JKD
MAGNESIUM	EPA 200.7	3.78 MG/L	J+,E	04/27/2009	15:46	JKD
MANGANESE	EPA 200.7	<0.0050 MG/L		04/28/2009	13:47	JKD
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:47	JKD
MERCURY	EPA 245.1	<0.0002 MG/L		04/27/2009	11:54	MAR
NICKEL	EPA 200.7	<0.0010 MG/L	N	04/28/2009	13:47	JKD
SELENIUM	EPA 200.7	<0.0020 MG/L	M	04/28/2009	13:47	JKD
SILVER	EPA 200.7	<0.0010 MG/L		04/28/2009	13:47	JKD
TIN	EPA 200.7	<0.0010 MG/L		04/28/2009	13:47	JKD
TITANIUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:47	JKD
THALLIUM	EPA 200.7	<0.0020 MG/L	M	04/28/2009	13:47	JKD
ZINC	EPA 200.7	0.0028 MG/L		04/28/2009	13:47	JKD
BORON	EPA 200.7	0.0058 MG/L	N	04/28/2009	13:47	JKD
SOLIDS, TOTAL SUSPENDED	SM 2540,D.	<1.00 MG/L		04/27/2009	11:00	KDW

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 4/25/2009
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 4/25/2009
 Permit No. 0000360

Work Order Number: 0904-01088

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
003 FINISHED 4/25/09 0630						
.....continued						
HARDNESS, TOTAL AS CaCO3	EPA 200.7;2340,B.	57.1 MG/L	J+	04/27/2009	15:46	JKD
004 FINISHED 4/25/09 0630 DISSOLVED METALS						
[TAL METALS]					00:00	
ALUMINUM	EPA 200.7	<0.0050 MG/L	N,*	04/28/2009	13:53	JKD
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	04/28/2009	13:53	JKD
ARSENIC	EPA 200.7	<0.0010 MG/L	M	04/28/2009	13:53	JKD
BARIUM	EPA 200.7	0.0178 MG/L		04/28/2009	13:53	JKD
BERYLLIUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:53	JKD
CADMIUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:53	JKD
CHROMIUM	EPA 200.7	<0.0010 MG/L	N	04/28/2009	13:53	JKD
COBALT	EPA 200.7	<0.0010 MG/L		04/28/2009	13:53	JKD
COPPER	EPA 200.7	0.0025 MG/L		04/28/2009	13:53	JKD
IRON	EPA 200.7	0.0116 MG/L		04/28/2009	13:53	JKD
LEAD	EPA 200.7	<0.0010 MG/L	M	04/28/2009	13:53	JKD
MAGNESIUM	EPA 200.7	4.20 MG/L	J+,E	04/27/2009	16:44	JKD
MANGANESE	EPA 200.7	<0.0050 MG/L		04/28/2009	13:53	JKD
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:53	JKD
MERCURY	EPA 245.1	<0.0002 MG/L		04/27/2009	11:57	MAR
NICKEL	EPA 200.7	<0.0010 MG/L	N	04/28/2009	13:53	JKD
SELENIUM	EPA 200.7	<0.0020 MG/L	M	04/28/2009	13:53	JKD
SILVER	EPA 200.7	<0.0010 MG/L		04/28/2009	13:53	JKD
TIN	EPA 200.7	<0.0010 MG/L		04/28/2009	13:53	JKD
TITANIUM	EPA 200.7	<0.0010 MG/L		04/28/2009	13:53	JKD

® **Microbac Laboratories, Inc.**



KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

PRELIMINARY REPORT

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 4/25/2009
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 4/25/2009
 Permit No. 0000360

Work Order Number: 0904-01088

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

004 **FINISHED 4/25/09 0630 DISSOLVED METALS**

.....continued

THALLIUM	EPA 200.7	<0.0020 MG/L	M	04/28/2009	13:53	JKD
ZINC	EPA 200.7	0.0057 MG/L		04/28/2009	13:53	JKD
BORON	EPA 200.7	0.0051 MG/L	N	04/28/2009	13:53	JKD
SILICA (SiO2)	EPA 200.7	2.19 MG/L		04/27/2009	16:44	JKD

M= THESE SAMPLES ARE REPORTED BY METHOD 200.7 FOR INFORMATIONAL PURPOSES TO PROVIDE QUICKER REPORTING. WHILE THESE REPORTED NUMBERS ARE CONSIDERED ACCURATE, TDEC APPROVED METHODS (EITHER 200.8 OR 200.9) ARE ALSO BEING ANALYZED AS VERIFICATION AND THIS REPORT WILL BE MODIFIED TO REFLECT THE METHOD CHANGE WHEN COMPLETE.

RESPECTFULLY SUBMITTED: _____

MICROBAC LABORATORIES, INC.

Thank you for your business. We invite your feedback on our level of service to you. Please contact the Laboratory Director, James Nokes, at 865-977-1200, the COO, Robert Morgan, at rmorgan@microbac.com or the CEO, Trevor Boyce, at tboyce@microbac.com with any comments or suggestions.

® **Microbac Laboratories, Inc.**

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 4/25/2009
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 4/25/2009
 Permit No. 0000360

Work Order Number: 0904-01088

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

As regulatory limits change frequently, Microbac advises the recipient of this report to confirm such limits with the appropriate Federal, state, or local authorities before acting in reliance on the regulatory limits provided.

Microbac Laboratories, Inc. cannot guarantee the confidentiality of any facsimile or e-mail transmittal. The information in this communication is intended for the exclusive use of the addressee. If you are not the intended recipient, you are notified that any disclosure, copying, distributing, or the taking of any action in reliance on the contents of this information is strictly prohibited. If you received this transmission in error, please notify us immediately.

QUALIFIER DEFINITIONS:

- B = Detected in the associated Method Blank
- C = As Tons CaCO₃, equivalent per 1,000 tons material
- D = Surrogate recoveries not calculated due to matrix interference and resulting sample dilution
- E1 = Elevated detection limits due to sample matrix interference
- E2 = Elevated detection limits due to high analyte concentration
- H = Analyte was prepared and/or analyzed outside of the analytical method holding time
- I = Spike recovery outside control limits due to sample matrix interference or high analyte concentration
- J = The result is an estimated quantity. The associated numerical value is the approximate concentration of the analyte in the sample
- J+ = The result is an estimated quantity, but the result may be biased high
- J- = The result is an estimated quantity, but the result may be biased low
- UJ = The analyte was analyzed for, but was not detected. The reported quantitation limit is approximate and may be inaccurate or imprecise
- K = Analyte concentration estimated due to sample matrix interference and/or high analyte concentration interference
- L1 = Liquid portion of dual phase sample analyzed only
- L2 = Solid portion of dual phase sample analyzed only
- M = Miscellaneous (see entry below analytical results)
- N = Analyte acceptable but matrix spike/matrix spike duplicate outside accepted recovery criteria
- * = Matrix Spike/Matrix Spike Duplicate RPD is outside acceptable limits
- P = Sample received improperly preserved
- R = Relative Percent Duplicate (RPD) outside accepted recovery limits
- S1 = Spike recovery outside recovery limits
- S2 = Surrogate recovery outside of control limits. The data was accepted based on the valid recovery of remaining surrogate.
- U = Undetected
- V = Elevated reporting limits due to insufficient sample volume
- W = Results reports on dry weight basis

ABBREVIATIONS:

- TNTC = Too Numerous To Count
- UG/L = Micrograms per Liter (PPB)
- UG/KG = Micrograms per Kilogram (PPB)
- MG/L = Milligrams per Liter (PPM)
- MG/KG = Milligrams per Kilogram (PPM)
- CFU = Colony Forming Unit
- ND = Not Detected at or below the reporting limit
- TIC = Tentatively Identified Compound



® **Microbac Laboratories, Inc.**

KNOXVILLE DIVISION
505 EAST BROADWAY AVE.
MARYVILLE, TN 37804
(865) 977-1200 FAX (865) 984-8616
http://www.microbac.com
E-Mail: knoxville@microbac.com

STATE CERT ID.
TN 02017



CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
CHUCK MOORE
125 W. CUMBERLAND ST.
KINGSTON, TN 37763

Date Reported
Date Received 4/25/2009
Cust P.O.
Invoice No.
Cust # C120
Sample Date 4/25/2009
Permit No. 0000360

Work Order Number: 0904-01088

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

