

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 12/5/2009
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 12/5/2009
 Permit No. 0000360

Work Order Number: 0912-00273

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
001 RAW 12/5/09 0630						
[TAL METALS]						
ALUMINUM	EPA 200.7	0.0202 MG/L	J+	12/08/2009	13:18	SRR
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	12/08/2009	13:18	SRR
ARSENIC	EPA 200.7	<0.0010 MG/L	M	12/08/2009	13:18	SRR
BARIUM	EPA 200.7	0.0196 MG/L		12/08/2009	13:18	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:18	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:18	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:18	SRR
COBALT	EPA 200.7	<0.0010 MG/L		12/08/2009	13:18	SRR
COPPER	EPA 200.7	0.0015 MG/L		12/08/2009	13:18	SRR
IRON	EPA 200.7	<0.0060 MG/L		12/08/2009	13:18	SRR
LEAD	EPA 200.7	<0.0010 MG/L	M	12/08/2009	13:18	SRR
MAGNESIUM	EPA 200.7	4.04 MG/L		12/07/2009	18:32	SRR
MANGANESE	EPA 200.7	<0.0050 MG/L		12/08/2009	13:18	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:18	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		12/07/2009	15:10	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		12/08/2009	13:18	SRR
SELENIUM	EPA 200.7	<0.0020 MG/L	M	12/08/2009	13:18	SRR
SILVER	EPA 200.7	<0.0010 MG/L		12/08/2009	13:18	SRR
TIN	EPA 200.7	<0.0010 MG/L		12/08/2009	13:18	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:18	SRR
THALLIUM	EPA 200.7	<0.0020 MG/L	M	12/08/2009	13:18	SRR
ZINC	EPA 200.7	0.0044 MG/L		12/08/2009	13:18	SRR
BORON	EPA 200.7	0.0098 MG/L		12/08/2009	13:18	SRR
SOLIDS, TOTAL SUSPENDED	SM 2540.D.	4.29 MG/L		12/07/2009	08:35	KDW
HARDNESS, TOTAL AS CaCO3	EPA 200.7;2340.B.	59.5 MG/L	J+	12/07/2009	18:32	SRR



KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

PRELIMINARY REPORT

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 12/5/2009
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 12/5/2009
 Permit No. 0000360

Work Order Number: 0912-00273

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

002 RAW 12/5/09 0630 DISSOLVED METALS

Test	Method	Result	Qual	Date	Time	Tech
[TAL METALS]					00:00	
ALUMINUM	EPA 200.7	0.0241 MG/L		12/08/2009	13:59	SRR
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	12/08/2009	13:59	SRR
ARSENIC	EPA 200.7	<0.0010 MG/L	M	12/08/2009	13:59	SRR
BARIUM	EPA 200.7	0.0200 MG/L		12/08/2009	13:59	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:59	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:59	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:59	SRR
COBALT	EPA 200.7	<0.0010 MG/L		12/08/2009	13:59	SRR
COPPER	EPA 200.7	0.0014 MG/L		12/08/2009	13:59	SRR
IRON	EPA 200.7	0.0195 MG/L		12/08/2009	13:59	SRR
LEAD	EPA 200.7	<0.0010 MG/L	M	12/08/2009	13:59	SRR
MAGNESIUM	EPA 200.7	3.60 MG/L		12/07/2009	18:48	SRR
MANGANESE	EPA 200.7	<0.0050 MG/L		12/08/2009	13:59	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:59	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		12/07/2009	15:18	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		12/08/2009	13:59	SRR
SELENIUM	EPA 200.7	<0.0020 MG/L	M	12/08/2009	13:59	SRR
SILVER	EPA 200.7	<0.0010 MG/L		12/08/2009	13:59	SRR
TIN	EPA 200.7	<0.0010 MG/L		12/08/2009	13:59	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:59	SRR
THALLIUM	EPA 200.7	<0.0020 MG/L	M	12/08/2009	13:59	SRR
ZINC	EPA 200.7	0.0176 MG/L		12/08/2009	13:59	SRR
BORON	EPA 200.7	0.0126 MG/L		12/08/2009	13:59	SRR
SILICA (SiO2)	EPA 200.7	5.42 MG/L		12/07/2009	18:48	SRR



Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 12/5/2009
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 12/5/2009
 Permit No. 0000360

Work Order Number: 0912-00273

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

003 **FINISHED 12/5/09 0630**

Test	Method	Result	Qual	Date	Time	Tech
[TAL METALS]					00:00	
ALUMINUM	EPA 200.7	0.193 MG/L	J+	12/08/2009	13:26	SRR
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	12/08/2009	13:26	SRR
ARSENIC	EPA 200.7	<0.0010 MG/L	M	12/08/2009	13:26	SRR
BARIUM	EPA 200.7	0.0211 MG/L		12/08/2009	13:26	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:26	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:26	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:26	SRR
COBALT	EPA 200.7	<0.0010 MG/L		12/08/2009	13:26	SRR
COPPER	EPA 200.7	0.0013 MG/L		12/08/2009	13:26	SRR
IRON	EPA 200.7	0.234 MG/L		12/08/2009	13:26	SRR
LEAD	EPA 200.7	<0.0010 MG/L	M	12/08/2009	13:26	SRR
MAGNESIUM	EPA 200.7	3.88 MG/L		12/07/2009	18:40	SRR
MANGANESE	EPA 200.7	0.0386 MG/L		12/08/2009	13:26	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		12/08/2009	13:26	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		12/07/2009	15:14	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		12/08/2009	13:26	SRR
SELENIUM	EPA 200.7	<0.0020 MG/L	M	12/08/2009	13:26	SRR
SILVER	EPA 200.7	<0.0010 MG/L		12/08/2009	13:26	SRR
TIN	EPA 200.7	<0.0010 MG/L		12/08/2009	13:26	SRR
TITANIUM	EPA 200.7	0.0041 MG/L		12/08/2009	13:26	SRR
THALLIUM	EPA 200.7	<0.0020 MG/L	M	12/08/2009	13:26	SRR
ZINC	EPA 200.7	0.0152 MG/L		12/08/2009	13:26	SRR
BORON	EPA 200.7	0.0097 MG/L		12/08/2009	13:26	SRR
SOLIDS, TOTAL SUSPENDED	SM 2540,D.	<4.00 MG/L		12/07/2009	08:35	KDW

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 12/5/2009
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 12/5/2009
 Permit No. 0000360

Work Order Number: 0912-00273

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
003 FINISHED 12/5/09 0630						
.....continued						
HARDNESS, TOTAL AS CaCO3	EPA 200.7;2340,B.	57.3 MG/L	J+	12/07/2009	18:40	SRR
004 FINISHED 12/5/09 0630 DISSOLVED METALS						
[TAL METALS]					00:00	
ALUMINUM	EPA 200.7	0.0358 MG/L		12/08/2009	14:07	SRR
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	12/08/2009	14:07	SRR
ARSENIC	EPA 200.7	<0.0010 MG/L	M	12/08/2009	14:07	SRR
BARIUM	EPA 200.7	0.0198 MG/L		12/08/2009	14:07	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	14:07	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	14:07	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	14:07	SRR
COBALT	EPA 200.7	<0.0010 MG/L		12/08/2009	14:07	SRR
COPPER	EPA 200.7	0.0016 MG/L		12/08/2009	14:07	SRR
IRON	EPA 200.7	<0.0060 MG/L		12/08/2009	14:07	SRR
LEAD	EPA 200.7	<0.0010 MG/L	M	12/08/2009	14:07	SRR
MAGNESIUM	EPA 200.7	3.95 MG/L		12/07/2009	18:57	SRR
MANGANESE	EPA 200.7	<0.0050 MG/L		12/08/2009	14:07	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		12/08/2009	14:07	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		12/07/2009	15:22	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		12/08/2009	14:07	SRR
SELENIUM	EPA 200.7	<0.0020 MG/L	M	12/08/2009	14:07	SRR
SILVER	EPA 200.7	<0.0010 MG/L		12/08/2009	14:07	SRR
TIN	EPA 200.7	<0.0010 MG/L		12/08/2009	14:07	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L		12/08/2009	14:07	SRR

® **Microbac Laboratories, Inc.**



KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

PRELIMINARY REPORT

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 12/5/2009
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 12/5/2009
 Permit No. 0000360

Work Order Number: 0912-00273

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

004 **FINISHED 12/5/09 0630 DISSOLVED METALS**

.....continued

THALLIUM	EPA 200.7	<0.0020 MG/L	M	12/08/2009	14:07	SRR
ZINC	EPA 200.7	0.0054 MG/L		12/08/2009	14:07	SRR
BORON	EPA 200.7	0.0142 MG/L		12/08/2009	14:07	SRR
SILICA (SiO2)	EPA 200.7	5.72 MG/L		12/07/2009	18:57	SRR

M= THESE SAMPLES ARE REPORTED BY METHOD 200.7 FOR INFORMATIONAL PURPOSES TO PROVIDE QUICKER REPORTING. WHILE THESE REPORTED NUMBERS ARE CONSIDERED ACCURATE, TDEC APPROVED METHODS (EITHER 200.8 OR 200.9) ARE ALSO BEING ANALYZED AS VERIFICATION AND THIS REPORT WILL BE MODIFIED TO REFLECT THE METHOD CHANGE WHEN COMPLETE.

RESPECTFULLY SUBMITTED: _____

MICROBAC LABORATORIES, INC.

Thank you for your business. We invite your feedback on our level of service to you. Please contact the Laboratory Director, James Nokes, at 865-977-1200, the COO, Robert Morgan, at rmorgan@microbac.com or the President, James Nokes, at jnokes@microbac.com with any comments or suggestions.



® **Microbac Laboratories, Inc.**

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 12/5/2009
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 12/5/2009
 Permit No. 0000360

Work Order Number: 0912-00273

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

As regulatory limits change frequently, Microbac advises the recipient of this report to confirm such limits with the appropriate Federal, state, or local authorities before acting in reliance on the regulatory limits provided.

Microbac Laboratories, Inc. cannot guarantee the confidentiality of any facsimile or e-mail transmittal. The information in this communication is intended for the exclusive use of the addressee. If you are not the intended recipient, you are notified that any disclosure, copying, distributing, or the taking of any action in reliance on the contents of this information is strictly prohibited. If you received this transmission in error, please notify us immediately.

QUALIFIER DEFINITIONS:

- B = Detected in the associated Method Blank
- C = As Tons CaCO₃, equivalent per 1,000 tons material
- D = Surrogate recoveries not calculated due to matrix interference and resulting sample dilution
- E1 = Elevated detection limits due to sample matrix interference
- E2 = Elevated detection limits due to high analyte concentration
- H = Analyte was prepared and/or analyzed outside of the analytical method holding time
- I = Spike recovery outside control limits due to sample matrix interference or high analyte concentration
- J = The result is an estimated quantity. The associated numerical value is the approximate concentration of the analyte in the sample
- J+ = The result is an estimated quantity, but the result may be biased high
- J- = The result is an estimated quantity, but the result may be biased low
- UJ = The analyte was analyzed for, but was not detected. The reported quantitation limit is approximate and may be inaccurate or imprecise
- K = Analyte concentration estimated due to sample matrix interference and/or high analyte concentration interference
- L1 = Liquid portion of dual phase sample analyzed only
- L2 = Solid portion of dual phase sample analyzed only
- M = Miscellaneous (see entry below analytical results)
- N = Analyte acceptable but matrix spike/matrix spike duplicate outside accepted recovery criteria
- * = Matrix Spike/Matrix Spike Duplicate RPD is outside acceptable limits
- P = Sample received improperly preserved
- R = Relative Percent Duplicate (RPD) outside accepted recovery limits
- S1 = Spike recovery outside recovery limits
- S2 = Surrogate recovery outside of control limits. The data was accepted based on the valid recovery of remaining surrogate.
- U = Undetected
- V = Elevated reporting limits due to insufficient sample volume
- W = Results reports on dry weight basis
- Z - The parameter is considered a field analysis with an immediate to 15 minute holding time. Laboratory analysis is confirmatory in nature and is performed outside the preferred holding time window.

ABBREVIATIONS:

- TNTC = Too Numerous To Count
- MG/KG = Milligrams per Kilogram (PPM)
- UG/L = Micrograms per Liter (PPB)
- CFU = Colony Forming Unit



® **Microbac Laboratories, Inc.**

Microbac

KNOXVILLE DIVISION
505 EAST BROADWAY AVE.
MARYVILLE, TN 37804
(865) 977-1200 FAX (865) 984-8616
<http://www.microbac.com>
E-Mail: knoxville@microbac.com

STATE CERT ID.
TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
CHUCK MOORE
125 W. CUMBERLAND ST.
KINGSTON, TN 37763

Date Reported
Date Received 12/5/2009
Cust P.O.
Invoice No.
Cust # C120
Sample Date 12/5/2009
Permit No. 0000360

Work Order Number: 0912-00273

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

