



Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/8/2010
 Date Received: 6/25/2010
 Cust #: RC120
 PO#:

Workorder: 1004326 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Raw Sampled: 06/25/2010 06:30
 1004326-01 (Water)

Wet Chemistry

Total Suspended Solids	4.0	mg/L		4.0	KDW	06/25/2010 09:30	SM 2540.D.
Metals by EPA 200 Series Methods							
Aluminum	0.119	mg/L	*, B, N	0.00500	SRR	06/29/2010 10:55	EPA 200.7
Barium	0.0334	mg/L		0.00200	SRR	06/29/2010 10:55	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	06/29/2010 10:55	EPA 200.7
Boron	0.0214	mg/L		0.00100	SRR	06/29/2010 10:55	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	06/29/2010 10:55	EPA 200.7
Chromium	ND	mg/L	U	0.00100	SRR	06/29/2010 10:55	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	06/29/2010 10:55	EPA 200.7
Copper	0.00345	mg/L		0.00100	SRR	06/29/2010 10:55	EPA 200.7
Hardness, Total as CaCO3	81.2	mg/L		0.145	SRR	06/29/2010 11:20	EPA 200.7, SM 2340B
Iron	0.0816	mg/L	D	0.00600	SRR	06/29/2010 10:55	EPA 200.7
Magnesium	5.96	mg/L	*	0.00500	SRR	06/29/2010 10:55	EPA 200.7
Manganese	0.0299	mg/L		0.00500	SRR	06/29/2010 10:55	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	06/29/2010 14:20	EPA 245.1
Molybdenum	0.00130	mg/L		0.00100	SRR	06/29/2010 10:55	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	06/29/2010 10:55	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	06/29/2010 10:55	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	06/29/2010 10:55	EPA 200.7
Titanium	0.00159	mg/L		0.00100	SRR	06/29/2010 10:55	EPA 200.7
Zinc	0.00880	mg/L	B	0.00200	SRR	06/29/2010 10:55	EPA 200.7
Subcontracted Analyses							
Antimony	ND	mg/L		0.00500	MTC	07/08/2010 09:34	EPA 200.8
Arsenic	ND	mg/L		0.00500	MTC	07/02/2010 13:53	EPA 200.8
Lead	ND	mg/L		0.00500	MTC	07/02/2010 13:53	EPA 200.8
Selenium	ND	mg/L		0.00500	MTC	07/02/2010 13:53	EPA 200.8
Thallium	ND	mg/L		0.00100	MTC	07/02/2010 13:53	EPA 200.8

Raw Dissolved Sampled: 06/25/2010 06:30
 1004326-02 (Water)

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/8/2010
 Date Received: 6/25/2010
 Cust #: RC120
 PO#:

Workorder: 1004326 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Raw Dissolved Sampled: 06/25/2010 06:30
 1004326-02 (Water)

Metals (Dissolved) by EPA 200 Series Methods

Aluminum	0.0243	mg/L		0.00500	SRR	06/29/2010 12:05	EPA 200.7
Barium	0.0319	mg/L	*	0.00200	SRR	06/29/2010 12:05	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	06/29/2010 12:05	EPA 200.7
Boron	0.0210	mg/L	B	0.00100	SRR	06/29/2010 12:05	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	06/29/2010 12:05	EPA 200.7
Chromium	ND	mg/L		0.00100	SRR	06/29/2010 12:05	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	06/29/2010 12:05	EPA 200.7
Copper	0.00195	mg/L	B	0.00100	SRR	06/29/2010 12:05	EPA 200.7
Iron	ND	mg/L		0.00600	SRR	06/29/2010 12:05	EPA 200.7
Magnesium	5.63	mg/L		0.00500	SRR	06/29/2010 12:05	EPA 200.7
Manganese	ND	mg/L		0.00500	SRR	06/29/2010 12:05	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	06/29/2010 15:18	EPA 245.1
Molybdenum	0.00123	mg/L		0.00100	SRR	06/29/2010 12:05	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	06/29/2010 12:05	EPA 200.7
SILICA (SiO2)	3.02	mg/L		0.0107	SRR	06/29/2010 12:05	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	06/29/2010 12:05	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	06/29/2010 12:05	EPA 200.7
Titanium	ND	mg/L		0.00100	SRR	06/29/2010 12:05	EPA 200.7
Zinc	0.00632	mg/L	B	0.00200	SRR	06/29/2010 12:05	EPA 200.7

Subcontracted Analyses

Antimony	ND	mg/L		0.00500	MTC	07/02/2010 14:19	EPA 200.8
Arsenic	ND	mg/L		0.00500	MTC	07/02/2010 14:19	EPA 200.8
Lead	ND	mg/L		0.00500	MTC	07/02/2010 14:19	EPA 200.8
Selenium	ND	mg/L		0.00500	MTC	07/02/2010 14:19	EPA 200.8
Thallium	ND	mg/L		0.00100	MTC	07/02/2010 14:19	EPA 200.8

Finished Sampled: 06/25/2010 06:30
 1004326-03 (Water)

Wet Chemistry

Total Suspended Solids	ND	mg/L		4.0	KDW	06/25/2010 09:30	SM 2540.D.
------------------------	----	------	--	-----	-----	------------------	------------

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/8/2010
 Date Received: 6/25/2010
 Cust #: RC120
 PO#:

Workorder: 1004326 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Finished Sampled: 06/25/2010 06:30
 1004326-03 (Water)

Metals by EPA 200 Series Methods

Aluminum	0.190	mg/L	*, B, N	0.00500	SRR	06/29/2010 11:27	EPA 200.7
Barium	0.0245	mg/L		0.00200	SRR	06/29/2010 11:27	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	06/29/2010 11:27	EPA 200.7
Boron	0.0158	mg/L		0.00100	SRR	06/29/2010 11:27	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	06/29/2010 11:27	EPA 200.7
Chromium	ND	mg/L	U	0.00100	SRR	06/29/2010 11:27	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	06/29/2010 11:27	EPA 200.7
Copper	0.00301	mg/L		0.00100	SRR	06/29/2010 11:27	EPA 200.7
Hardness, Total as CaCO3	64.1	mg/L		0.0331	SRR	06/29/2010 11:27	EPA 200.7, SM 2340B
Iron	ND	mg/L		0.00600	SRR	06/29/2010 11:27	EPA 200.7
Magnesium	4.72	mg/L	*	0.00500	SRR	06/29/2010 11:27	EPA 200.7
Manganese	ND	mg/L		0.00500	SRR	06/29/2010 11:27	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	06/29/2010 14:24	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	06/29/2010 11:27	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	06/29/2010 11:27	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	06/29/2010 11:27	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	06/29/2010 11:27	EPA 200.7
Titanium	ND	mg/L		0.00100	SRR	06/29/2010 11:27	EPA 200.7
Zinc	0.00215	mg/L	B	0.00200	SRR	06/29/2010 11:27	EPA 200.7

Subcontracted Analyses

Antimony	ND	mg/L		0.00500	MTC	07/02/2010 14:42	EPA 200.8
Arsenic	ND	mg/L		0.00500	MTC	07/02/2010 14:42	EPA 200.8
Lead	ND	mg/L		0.00500	MTC	07/02/2010 14:42	EPA 200.8
Selenium	ND	mg/L		0.00500	MTC	07/02/2010 14:42	EPA 200.8
Thallium	ND	mg/L		0.00100	MTC	07/02/2010 14:42	EPA 200.8

Finished Dissolved Sampled: 06/25/2010 06:30
 1004326-04 (Water)

Metals (Dissolved) by EPA 200 Series Methods

Aluminum	0.150	mg/L		0.00500	SRR	06/29/2010 12:12	EPA 200.7
----------	-------	------	--	---------	-----	------------------	-----------

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
<http://www.microbac.com>
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/8/2010
 Date Received: 6/25/2010
 Cust #: RC120
 PO#:

Workorder: 1004326 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Finished Dissolved Sampled: 06/25/2010 06:30
 1004326-04 (Water)

Metals (Dissolved) by EPA 200 Series Methods

Barium	0.0264	mg/L	*	0.00200	SRR	06/29/2010 12:12	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	06/29/2010 12:12	EPA 200.7
Boron	0.0153	mg/L	B	0.00100	SRR	06/29/2010 12:12	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	06/29/2010 12:12	EPA 200.7
Chromium	ND	mg/L		0.00100	SRR	06/29/2010 12:12	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	06/29/2010 12:12	EPA 200.7
Copper	0.00280	mg/L	B	0.00100	SRR	06/29/2010 12:12	EPA 200.7
Iron	ND	mg/L		0.00600	SRR	06/29/2010 12:12	EPA 200.7
Magnesium	4.48	mg/L		0.00500	SRR	06/29/2010 12:12	EPA 200.7
Manganese	ND	mg/L		0.00500	SRR	06/29/2010 12:12	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	06/29/2010 15:22	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	06/29/2010 12:12	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	06/29/2010 12:12	EPA 200.7
SILICA (SiO2)	3.42	mg/L		0.0107	SRR	06/29/2010 12:12	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	06/29/2010 12:12	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	06/29/2010 12:12	EPA 200.7
Titanium	ND	mg/L		0.00100	SRR	06/29/2010 12:12	EPA 200.7
Zinc	0.0190	mg/L	B	0.00200	SRR	06/29/2010 12:12	EPA 200.7

Subcontracted Analyses

Antimony	ND	mg/L		0.00500	MTC	07/02/2010 14:46	EPA 200.8
Arsenic	ND	mg/L		0.00500	MTC	07/02/2010 14:46	EPA 200.8
Lead	ND	mg/L		0.00500	MTC	07/02/2010 14:46	EPA 200.8
Selenium	ND	mg/L		0.00500	MTC	07/02/2010 14:46	EPA 200.8
Thallium	ND	mg/L		0.00100	MTC	07/02/2010 14:46	EPA 200.8

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
<http://www.microbac.com>
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/8/2010
 Date Received: 6/25/2010
 Cust #: RC120
 PO#:

Workorder: 1004326 **Project:** Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Certifications

Code	Description	Number	Expires
IN_DW	Indiana State Department of Health	C-TN-03	04/30/2011
PA	Commonwealth of Pennsylvania	68-00725 (003)	03/31/2011
TN_DW	State of Tennessee	TN02017	04/30/2011
USDA	US Department of Agriculture		11/30/2010

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/8/2010
 Date Received: 6/25/2010
 Cust #: RC120
 PO#:

Workorder: 1004326 **Project:** Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Notes and Definitions

- U Undetected
- N Analyte acceptable but matrix spike/matrix spike duplicate outside accepted recovery criteria
- J+ The result is an estimated quantity, but the result may be biased high
- E Concentration exceeds calibration range
- D Surrogate recoveries not calculated due to matrix interference and resulting sample dilution
- B Detected in the associated Method Blank
- * Relative Percent Duplicate (RPD) outside accepted recovery limits.
- DET Analyte DETECTED
- ND Analyte NOT DETECTED at or above the reporting limit
- NR Not Reported
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/8/2010
 Date Received: 6/25/2010
 Cust #: RC120
 PO#:

Workorder: 1004326 **Project:** Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Microbac Knoxville

JOE SLOAN For BROCK STONER, PROJECT MANAGER

Thank you for your business. We invite your feedback on our level of service to you. Please contact the Laboratory Director, Ashley Morris, at 865-977-1200, the COO, Robert Morgan, at rmorgan@microbac.com or the President, James Nokes, at jnokes@microbac.com with any comments or suggestions.

As regulatory limits change frequently, Microbac advises the recipient of this report to confirm such limits with the appropriate Federal, state, or local authorities before acting in reliance on the regulatory limits provided.


The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER



1004326-01 A Raw

City of Kingston Sampled: 06/25/2010 06:30
Water-B-1000ml Plastic HNO3 to pH <2



Microbac
MICROBAC LABORATORIES, INC
KNOXVILLE DIVISION
505 EAST BROADWAY
MARYVILLE, TN 37804
PHONE: (865) 977-1200 FAX: (865) 984-8616

Water System Name: KINGSTON WATER
Report to: Chuck Moore Invoice to: James Pinkerton
Address: 125 W. CUMBERLAND ST. Address: Same
KINGSTON, TN 37763
Phone: 865-376-7187 Fax: 865-376-1654 P.O. #:
E-mail: kingstonswater@bellsouth.net Quote #:


(1) Sample Matrix
DW = Drinking Water RW = Reagent Water
GW = Ground Water SW = Surface Water
(2) Sample Type
B = Entry Point E = Composite
D = Distribution S = Special

Sample Identification	Sample Date	Sample Time	Sample Matrix	Sample Type	# of Containers	Total Metals	Dissolved Metals	TSS	Hardness	Dissolved Silica
Raw	6/25/10	0630	DW		4	X	X	X	X	X
Finished	6/25/10	0630	DW		4	X	X	X	X	X

FOR LAB CHECK-IN ONLY
Temp Rec'd: 41.8 °C
Preserved: Yes No
Remarks: Metals maintainers

Collected By: Ed Roberts Initial
Steve McKeethan
David Banks D.B.
Please Print
Date: 6/25/10
Time: 8:15
Relinquished By: Steve McKeethan
Date: 6/25/10
Time: 8:15

Special Instructions / Comments...
* All are grab samples.
* Placed immediately on ice.
* Finish samples are Chlorinated.
Customer #: C120
Project: C120-COK01
Job Temp.:
- 43.26 -
Received By: [Signature]
Date: [Blank]
Time: [Blank]



Cooler Inspection Form

Client Name: Kingston Water

Date/Time Received: 6/25/10 8:15

Work Order: 1004326

No. of Samples: 2

Received By: AJB

Checklist Completed By: AJB

Carrier: FedEx() UPS() Client() Field Services() Other(): _____

- | | | | |
|---|---|--|---|
| After-Hours Receipt? | Yes <input type="checkbox"/> | No <input checked="" type="checkbox"/> | |
| Shipping container in good condition? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | Not Present <input type="checkbox"/> |
| Custody seals intact on cooler? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | Not Present <input checked="" type="checkbox"/> |
| Custody seals intact on samples? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | Not Present <input checked="" type="checkbox"/> |
| Chain of custody present? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody includes proper client information? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody includes proper collection information and signatures? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody includes dates and times of sample collection? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody includes proper sample descriptions? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody agrees with sample labels? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody identifies proper sample matrix? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody identifies proper number of samples? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody includes required analysis? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Samples are in proper containers/bottles? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Sample containers are intact? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Sufficient sample volume collected for requested analysis? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| VOA vials for aqueous samples have zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | Not Present <input checked="" type="checkbox"/> |
| Samples received within holding times? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Samples received on ice? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Sample properly preserved? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |

If No, adjusted by? _____ Date/Time: _____

Remarks: _____

ANY "NO" EVALUATION REQUIRES CLIENT NOTIFICATION (excluding After-Hours Receipt).

Comments: _____
