



Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
<http://www.microbac.com>
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/19/2010
 Date Received: 7/7/2010
 Cust #: RC120
 PO#:

Workorder: 1004740 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Raw Sampled: 07/07/2010 06:30

1004740-01 (Water)

Wet Chemistry

Total Suspended Solids	ND	mg/L		4.0	KDW	07/07/2010 09:30	SM 2540.D.
------------------------	----	------	--	-----	-----	------------------	------------

Metals by EPA 200 Series Methods

Aluminum	0.0962	mg/L	N	0.00500	SRR	07/09/2010 19:52	EPA 200.7
Barium	0.0231	mg/L		0.00200	SRR	07/09/2010 19:52	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	07/09/2010 19:52	EPA 200.7
Boron	0.0161	mg/L	B, J+	0.00100	SRR	07/09/2010 19:52	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	07/09/2010 19:52	EPA 200.7
Chromium	ND	mg/L		0.00100	SRR	07/09/2010 19:52	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	07/09/2010 19:52	EPA 200.7
Copper	0.00187	mg/L		0.00100	SRR	07/09/2010 19:52	EPA 200.7
Hardness, Total as CaCO3	56.7	mg/L		0.0331	SRR	07/09/2010 19:52	EPA 200.7, SM 2340B
Iron	0.0934	mg/L	D	0.00600	SRR	07/09/2010 19:52	EPA 200.7
Magnesium	4.02	mg/L	B	0.00500	SRR	07/09/2010 19:52	EPA 200.7
Manganese	0.0301	mg/L		0.00500	SRR	07/09/2010 19:52	EPA 200.7
Mercury	ND	mg/L		0.000200	MTC	07/15/2010 13:00	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	07/09/2010 19:52	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	07/09/2010 19:52	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	07/09/2010 19:52	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	07/09/2010 19:52	EPA 200.7
Titanium	0.00168	mg/L		0.00100	SRR	07/09/2010 19:52	EPA 200.7
Zinc	0.00698	mg/L	B	0.00200	SRR	07/09/2010 19:52	EPA 200.7

Metals by EPA 200 Series Methods

Antimony	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Arsenic	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Lead	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Selenium	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Thallium	<0.001	mg/L		0.00100	AM	07/12/2010 14:51	EPA 200.8

Raw Dissolved Sampled: 07/07/2010 06:30

1004740-02 (Water)

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/19/2010
 Date Received: 7/7/2010
 Cust #: RC120
 PO#:

Workorder: 1004740 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Raw Dissolved Sampled: 07/07/2010 06:30
1004740-02 (Water)

Metals (Dissolved) by EPA 200 Series Methods

Aluminum	0.0151	mg/L		0.00500	SRR	07/09/2010 20:04	EPA 200.7
Barium	0.0235	mg/L	B	0.00200	SRR	07/09/2010 20:04	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	07/09/2010 20:04	EPA 200.7
Boron	0.0138	mg/L	J+	0.00100	SRR	07/09/2010 20:04	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	07/09/2010 20:04	EPA 200.7
Chromium	ND	mg/L		0.00100	SRR	07/09/2010 20:04	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	07/09/2010 20:04	EPA 200.7
Copper	0.00118	mg/L		0.00100	SRR	07/09/2010 20:04	EPA 200.7
Iron	ND	mg/L		0.00600	SRR	07/09/2010 20:04	EPA 200.7
Magnesium	3.96	mg/L		0.00500	SRR	07/09/2010 20:04	EPA 200.7
Manganese	ND	mg/L		0.00500	SRR	07/09/2010 20:04	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	07/09/2010 18:18	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	07/09/2010 20:04	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	07/09/2010 20:04	EPA 200.7
SILICA (SiO2)	3.96	mg/L		0.0107	SRR	07/09/2010 20:04	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	07/09/2010 20:04	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	07/09/2010 20:04	EPA 200.7
Titanium	ND	mg/L		0.00100	SRR	07/09/2010 20:04	EPA 200.7
Zinc	0.00281	mg/L	B	0.00200	SRR	07/09/2010 20:04	EPA 200.7

Metals (Dissolved) by EPA 200 Series Methods

Antimony	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Arsenic	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Lead	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Selenium	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Thallium	<0.001	mg/L		0.00100	AM	07/12/2010 14:51	EPA 200.8

Finished Sampled: 07/07/2010 06:30
1004740-03 (Water)

Wet Chemistry

Total Suspended Solids	ND	mg/L		4.0	KDW	07/07/2010 09:30	SM 2540.D.
------------------------	----	------	--	-----	-----	------------------	------------

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/19/2010
 Date Received: 7/7/2010
 Cust #: RC120
 PO#:

Workorder: 1004740 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Finished Sampled: 07/07/2010 06:30
 1004740-03 (Water)

Metals by EPA 200 Series Methods

Aluminum	0.104	mg/L	N	0.00500	SRR	07/09/2010 19:58	EPA 200.7
Barium	0.0215	mg/L		0.00200	SRR	07/09/2010 19:58	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	07/09/2010 19:58	EPA 200.7
Boron	0.0138	mg/L	B, J+	0.00100	SRR	07/09/2010 19:58	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	07/09/2010 19:58	EPA 200.7
Chromium	ND	mg/L		0.00100	SRR	07/09/2010 19:58	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	07/09/2010 19:58	EPA 200.7
Copper	0.00290	mg/L		0.00100	SRR	07/09/2010 19:58	EPA 200.7
Hardness, Total as CaCO3	54.3	mg/L		0.0331	SRR	07/09/2010 19:58	EPA 200.7, SM 2340B
Iron	ND	mg/L		0.00600	SRR	07/09/2010 19:58	EPA 200.7
Magnesium	3.73	mg/L		0.00500	SRR	07/09/2010 19:58	EPA 200.7
Manganese	ND	mg/L		0.00500	SRR	07/09/2010 19:58	EPA 200.7
Mercury	ND	mg/L		0.000200	MTC	07/15/2010 13:00	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	07/09/2010 19:58	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	07/09/2010 19:58	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	07/09/2010 19:58	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	07/09/2010 19:58	EPA 200.7
Titanium	ND	mg/L		0.00100	SRR	07/09/2010 19:58	EPA 200.7
Zinc	0.00479	mg/L	B	0.00200	SRR	07/09/2010 19:58	EPA 200.7

Metals by EPA 200 Series Methods

Antimony	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Arsenic	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Lead	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Selenium	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Thallium	<0.001	mg/L		0.00100	AM	07/12/2010 14:51	EPA 200.8

Finished Dissolved Sampled: 07/07/2010 06:30
 1004740-04 (Water)

Metals (Dissolved) by EPA 200 Series Methods

Aluminum	0.0890	mg/L		0.00500	SRR	07/09/2010 20:10	EPA 200.7
----------	--------	------	--	---------	-----	------------------	-----------

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
<http://www.microbac.com>
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/19/2010
 Date Received: 7/7/2010
 Cust #: RC120
 PO#:

Workorder: 1004740 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Finished Dissolved Sampled: 07/07/2010 06:30
 1004740-04 (Water)

Metals (Dissolved) by EPA 200 Series Methods

Barium	0.0208	mg/L	B	0.00200	SRR	07/09/2010 20:10	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	07/09/2010 20:10	EPA 200.7
Boron	0.0127	mg/L	J+	0.00100	SRR	07/09/2010 20:10	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	07/09/2010 20:10	EPA 200.7
Chromium	ND	mg/L		0.00100	SRR	07/09/2010 20:10	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	07/09/2010 20:10	EPA 200.7
Copper	0.00271	mg/L		0.00100	SRR	07/09/2010 20:10	EPA 200.7
Iron	ND	mg/L		0.00600	SRR	07/09/2010 20:10	EPA 200.7
Magnesium	3.57	mg/L		0.00500	SRR	07/09/2010 20:10	EPA 200.7
Manganese	ND	mg/L		0.00500	SRR	07/09/2010 20:10	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	07/09/2010 18:23	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	07/09/2010 20:10	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	07/09/2010 20:10	EPA 200.7
SILICA (SiO2)	4.16	mg/L		0.0107	SRR	07/09/2010 20:10	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	07/09/2010 20:10	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	07/09/2010 20:10	EPA 200.7
Titanium	ND	mg/L		0.00100	SRR	07/09/2010 20:10	EPA 200.7
Zinc	0.00849	mg/L	B	0.00200	SRR	07/09/2010 20:10	EPA 200.7

Metals (Dissolved) by EPA 200 Series Methods

Antimony	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Arsenic	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Lead	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Selenium	<0.005	mg/L		0.00500	AM	07/12/2010 14:51	EPA 200.8
Thallium	<0.001	mg/L		0.00100	AM	07/12/2010 14:51	EPA 200.8

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/19/2010
 Date Received: 7/7/2010
 Cust #: RC120
 PO#:

Workorder: 1004740 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Certifications

Code	Description	Number	Expires
EPA	Environmental Protection Agency	TN00020	
IN_DW	Indiana State Department of Health	C-TN-03	04/30/2011
KY_DW	Commonwealth of Kentucky	90067	12/31/2010
NELAP	Florida Department of Health	E87978	06/30/2010
PA	Commonwealth of Pennsylvania	68-00725 (003)	03/31/2011
TN_DW	State of Tennessee	TN02003	03/12/2011
TN_DW	State of Tennessee	TN02017	04/30/2011
USDA	US Department of Agriculture		11/30/2010
VA_DW	Commonwealth of Virginia	00335	06/30/2010
WV_DW	West Virginia Department of Health and Human Resou	9956 C	12/31/2010

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/19/2010
 Date Received: 7/7/2010
 Cust #: RC120
 PO#:

Workorder: 1004740 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Notes and Definitions

- N Analyte acceptable but matrix spike/matrix spike duplicate outside accepted recovery criteria
- M2 <0.005
- M1 <0.001
- J+ The result is an estimated quantity, but the result may be biased high
- J- The result is an estimated quantity, but the result may be biased low
- D Surrogate recoveries not calculated due to matrix interference and resulting sample dilution
- B Detected in the associated Method Blank
- * Relative Percent Duplicate (RPD) outside accepted recovery limits.
- DET Analyte DETECTED
- ND Analyte NOT DETECTED at or above the reporting limit
- NR Not Reported
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 7/19/2010
 Date Received: 7/7/2010
 Cust #: RC120
 PO#:

Workorder: 1004740 **Project:** Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Microbac Knoxville

JOE SLOAN For BROCK STONER, PROJECT MANAGER

Thank you for your business. We invite your feedback on our level of service to you. Please contact the Laboratory Director, Ashley Morris, at 865-977-1200, the COO, Robert Morgan, at rmorgan@microbac.com or the President, James Nokes, at jnokes@microbac.com with any comments or suggestions.


As regulatory limits change frequently, Microbac advises the recipient of this report to confirm such limits with the appropriate Federal, state, or local authorities before acting in reliance on the regulatory limits provided.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER



Microbac Laboratories Inc.
505 E. Broadway Ave.
Maryville, TN 37804



Main: (865) 977-1200
Fax: (865) 984-8616
www.microbac.com

Cooler Inspection Form

Client Name: Kingston Water

Date/Time Received: 7/7/10 8:05

Work Order: 1004740

No. of Samples: 2

Received By: DG

Checklist Completed By: AUB

Carrier: FedEx() UPS() Client() Field Services() Other(): _____

- | | | | |
|---|---|--|---|
| After-Hours Receipt? | Yes <input type="checkbox"/> | No <input checked="" type="checkbox"/> | |
| Shipping container in good condition? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | Not Present <input type="checkbox"/> |
| Custody seals intact on cooler? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | Not Present <input checked="" type="checkbox"/> |
| Custody seals intact on samples? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | Not Present <input checked="" type="checkbox"/> |
| Chain of custody present? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody includes proper client information? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody includes proper collection information and signatures? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody includes dates and times of sample collection? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody includes proper sample descriptions? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody agrees with sample labels? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody identifies proper sample matrix? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody identifies proper number of samples? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody includes required analysis? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Samples are in proper containers/bottles? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Sample containers are intact? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Sufficient sample volume collected for requested analysis? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| VOA vials for aqueous samples have zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | Not Present <input checked="" type="checkbox"/> |
| Samples received within holding times? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Samples received on ice? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Sample properly preserved? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |

If No, adjusted by? _____ Date/Time: _____

Remarks: _____

ANY "NO" EVALUATION REQUIRES CLIENT NOTIFICATION (excluding After-Hours Receipt).

Comments: _____