



Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
<http://www.microbac.com>
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/17/2010
 Date Received: 8/11/2010
 Cust #: RC120
 PO#:

Workorder: 1006418 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Raw Sampled: 08/11/2010 06:30

1006418-01 (Water)

Wet Chemistry

Total Suspended Solids	8.1	mg/L		4.0	KDW	08/11/2010 11:00	SM 2540.D.
------------------------	-----	------	--	-----	-----	------------------	------------

Metals by EPA 200 Series Methods

Aluminum	0.306	mg/L	N	0.00500	SRR	08/13/2010 11:49	EPA 200.7
Barium	0.0254	mg/L		0.00200	SRR	08/13/2010 11:49	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	08/13/2010 11:49	EPA 200.7
Boron	0.0117	mg/L	B, J+	0.00100	SRR	08/13/2010 11:49	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	08/13/2010 11:49	EPA 200.7
Chromium	0.00141	mg/L		0.00100	SRR	08/13/2010 11:49	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	08/13/2010 11:49	EPA 200.7
Copper	0.00285	mg/L		0.00100	SRR	08/13/2010 11:49	EPA 200.7
Hardness, Total as CaCO3	68.2	mg/L		0.0331	SRR	08/13/2010 11:49	EPA 200.7, SM 2340B
Iron	0.222	mg/L		0.00600	SRR	08/13/2010 11:49	EPA 200.7
Magnesium	4.64	mg/L	B	0.00500	SRR	08/13/2010 11:49	EPA 200.7
Manganese	0.0410	mg/L		0.00500	SRR	08/13/2010 11:49	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	08/12/2010 13:37	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	08/13/2010 11:49	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	08/13/2010 11:49	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	08/13/2010 11:49	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	08/13/2010 11:49	EPA 200.7
Titanium	0.00575	mg/L		0.00100	SRR	08/13/2010 11:49	EPA 200.7
Zinc	0.0296	mg/L	B	0.00200	SRR	08/13/2010 11:49	EPA 200.7

Metals by EPA 200 Series Methods

Antimony	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Arsenic	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Lead	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Selenium	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Thallium	ND	mg/L		0.00100	AM	08/13/2010 13:39	EPA 200.8

Raw Dissolved Sampled: 08/11/2010 06:30

1006418-02 (Water)

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/17/2010
 Date Received: 8/11/2010
 Cust #: RC120
 PO#:

Workorder: 1006418 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Raw Dissolved Sampled: 08/11/2010 06:30
 1006418-02 (Water)

Metals (Dissolved) by EPA 200 Series Methods

Aluminum	0.0103	mg/L		0.00500	SRR	08/13/2010 12:52	EPA 200.7
Barium	0.0228	mg/L		0.00200	SRR	08/13/2010 12:52	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	08/13/2010 12:52	EPA 200.7
Boron	0.0174	mg/L	B, J+	0.00100	SRR	08/13/2010 12:52	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	08/13/2010 12:52	EPA 200.7
Chromium	ND	mg/L		0.00100	SRR	08/13/2010 12:52	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	08/13/2010 12:52	EPA 200.7
Copper	0.00195	mg/L		0.00100	SRR	08/13/2010 12:52	EPA 200.7
Iron	ND	mg/L		0.00600	SRR	08/13/2010 12:52	EPA 200.7
Magnesium	4.62	mg/L	B, J+	0.00500	SRR	08/13/2010 12:52	EPA 200.7
Manganese	ND	mg/L		0.00500	SRR	08/13/2010 12:52	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	08/12/2010 13:45	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	08/13/2010 12:52	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	08/13/2010 12:52	EPA 200.7
SILICA (SiO2)	4.93	mg/L		0.0107	SRR	08/16/2010 12:41	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	08/13/2010 12:52	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	08/13/2010 12:52	EPA 200.7
Titanium	ND	mg/L		0.00100	SRR	08/13/2010 12:52	EPA 200.7
Zinc	0.00647	mg/L	B, J+	0.00200	SRR	08/13/2010 12:52	EPA 200.7

Metals (Dissolved) by EPA 200 Series Methods

Antimony	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Arsenic	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Lead	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Selenium	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Thallium	ND	mg/L		0.00100	AM	08/13/2010 13:39	EPA 200.8

Finished Sampled: 08/11/2010 06:30
 1006418-03 (Water)

Wet Chemistry

Total Suspended Solids	ND	mg/L		4.0	KDW	08/11/2010 11:00	SM 2540.D.
------------------------	----	------	--	-----	-----	------------------	------------

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/17/2010
 Date Received: 8/11/2010
 Cust #: RC120
 PO#:

Workorder: 1006418 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Finished Sampled: 08/11/2010 06:30
 1006418-03 (Water)

Metals by EPA 200 Series Methods

Aluminum	0.124	mg/L	N	0.00500	SRR	08/13/2010 12:18	EPA 200.7
Barium	0.0217	mg/L		0.00200	SRR	08/13/2010 12:18	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	08/13/2010 12:18	EPA 200.7
Boron	0.0127	mg/L	B, J+	0.00100	SRR	08/13/2010 12:18	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	08/13/2010 12:18	EPA 200.7
Chromium	ND	mg/L		0.00100	SRR	08/13/2010 12:18	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	08/13/2010 12:18	EPA 200.7
Copper	0.00311	mg/L		0.00100	SRR	08/13/2010 12:18	EPA 200.7
Hardness, Total as CaCO3	68.9	mg/L		0.0331	SRR	08/13/2010 12:18	EPA 200.7, SM 2340B
Iron	0.00730	mg/L		0.00600	SRR	08/13/2010 12:18	EPA 200.7
Magnesium	4.71	mg/L	B	0.00500	SRR	08/13/2010 12:18	EPA 200.7
Manganese	ND	mg/L		0.00500	SRR	08/13/2010 12:18	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	08/12/2010 13:41	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	08/13/2010 12:18	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	08/13/2010 12:18	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	08/13/2010 12:18	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	08/13/2010 12:18	EPA 200.7
Titanium	ND	mg/L		0.00100	SRR	08/13/2010 12:18	EPA 200.7
Zinc	0.00659	mg/L	B	0.00200	SRR	08/13/2010 12:18	EPA 200.7

Metals by EPA 200 Series Methods

Antimony	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Arsenic	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Lead	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Selenium	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Thallium	ND	mg/L		0.00100	AM	08/13/2010 13:39	EPA 200.8

Finished Dissolved Sampled: 08/11/2010 06:30
 1006418-04 (Water)

Metals (Dissolved) by EPA 200 Series Methods

Aluminum	0.120	mg/L		0.00500	SRR	08/13/2010 12:57	EPA 200.7
----------	-------	------	--	---------	-----	------------------	-----------

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/17/2010
 Date Received: 8/11/2010
 Cust #: RC120
 PO#:

Workorder: 1006418 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Finished Dissolved Sampled: 08/11/2010 06:30
 1006418-04 (Water)

Metals (Dissolved) by EPA 200 Series Methods

Barium	0.0202	mg/L		0.00200	SRR	08/13/2010 12:57	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	08/13/2010 12:57	EPA 200.7
Boron	0.0129	mg/L	B, J+	0.00100	SRR	08/13/2010 12:57	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	08/13/2010 12:57	EPA 200.7
Chromium	ND	mg/L		0.00100	SRR	08/13/2010 12:57	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	08/13/2010 12:57	EPA 200.7
Copper	0.00277	mg/L		0.00100	SRR	08/13/2010 12:57	EPA 200.7
Iron	0.00625	mg/L		0.00600	SRR	08/13/2010 12:57	EPA 200.7
Magnesium	4.42	mg/L	B, J+	0.00500	SRR	08/13/2010 12:57	EPA 200.7
Manganese	ND	mg/L		0.00500	SRR	08/13/2010 12:57	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	08/12/2010 13:49	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	08/13/2010 12:57	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	08/13/2010 12:57	EPA 200.7
SILICA (SiO2)	4.65	mg/L		0.0107	SRR	08/16/2010 12:47	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	08/13/2010 12:57	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	08/13/2010 12:57	EPA 200.7
Titanium	ND	mg/L		0.00100	SRR	08/13/2010 12:57	EPA 200.7
Zinc	0.00649	mg/L	B, J+	0.00200	SRR	08/13/2010 12:57	EPA 200.7

Metals (Dissolved) by EPA 200 Series Methods

Antimony	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Arsenic	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Lead	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Selenium	ND	mg/L		0.00500	AM	08/13/2010 13:39	EPA 200.8
Thallium	ND	mg/L		0.00100	AM	08/13/2010 13:39	EPA 200.8

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
<http://www.microbac.com>
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/17/2010
 Date Received: 8/11/2010
 Cust #: RC120
 PO#:

Workorder: 1006418 **Project:** Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Certifications

Code	Description	Number	Expires
EPA	Environmental Protection Agency	TN00020	
IN_DW	Indiana State Department of Health	C-TN-03	04/30/2011
KY_DW	Commonwealth of Kentucky	90067	12/31/2010
NELAP	Florida Department of Health	E87978	06/30/2010
PA	Commonwealth of Pennsylvania	68-00725 (003)	03/31/2011
TN_DW	State of Tennessee	TN02003	03/12/2011
TN_DW	State of Tennessee	TN02017	04/30/2011
USDA	US Department of Agriculture		11/30/2010
VA_DW	Commonwealth of Virginia	00335	06/30/2010
WV_DW	West Virginia Department of Health and Human Resou	9956 C	12/31/2010

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/17/2010
 Date Received: 8/11/2010
 Cust #: RC120
 PO#:

Workorder: 1006418 **Project:** Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Notes and Definitions

- N Analyte acceptable but matrix spike/matrix spike duplicate outside accepted recovery criteria
- J+ The result is an estimated quantity, but the result may be biased high
- B Detected in the associated Method Blank
- DET Analyte DETECTED
- ND Analyte NOT DETECTED at or above the reporting limit
- NR Not Reported
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
<http://www.microbac.com>
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/17/2010
 Date Received: 8/11/2010
 Cust #: RC120
 PO#:

Workorder: 1006418 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Microbac Knoxville

JOE SLOAN, LAB MANAGER

Thank you for your business. We invite your feedback on our level of service to you. Please contact the Laboratory Director, Ashley Morris, at 865-977-1200, the COO, Robert Morgan, at rmorgan@microbac.com or the President, James Nokes, at jnokes@microbac.com with any comments or suggestions.

As regulatory limits change frequently, Microbac advises the recipient of this report to confirm such limits with the appropriate Federal, state, or local authorities before acting in reliance on the regulatory limits provided.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Cooler Inspection Form

Client Name: Kingston Water Date/Time Received: 8/11/10 800
Work Order: 1006418 No. of Samples: 2
Received By: AUB Checklist Completed By: AUB 1

Carrier: FedEx() UPS() Client() Field Services() Other(): _____

- After-Hours Receipt? Yes No
- Shipping container in good condition? Yes No Not Present
- Custody seals intact on cooler? Yes No Not Present
- Custody seals intact on samples? Yes No Not Present
- Chain of custody present? Yes No
- Chain of custody includes proper client information? Yes No
- Chain of custody includes proper collection information and signatures? Yes No
- Chain of custody includes dates and times of sample collection? Yes No
- Chain of custody includes proper sample descriptions? Yes No
- Chain of custody agrees with sample labels? Yes No
- Chain of custody identifies proper sample matrix? Yes No
- Chain of custody identifies proper number of samples? Yes No
- Chain of custody includes required analysis? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Samples are in proper containers/bottles? Yes No
- Sample containers are intact? Yes No
- Sufficient sample volume collected for requested analysis? Yes No
- VOA vials for aqueous samples have zero headspace? Yes No Not Present
- Samples received within holding times? Yes No
- Samples received on ice? Yes No
- Sample properly preserved? Yes No

If No, adjusted by? _____ Date/Time: _____

Remarks: _____

ANY "NO" EVALUATION REQUIRES CLIENT NOTIFICATION (excluding After-Hours Receipt).

Comments: _____