



Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
<http://www.microbac.com>
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/23/2010
 Date Received: 8/17/2010
 Cust #: RC120
 PO#:

Workorder: 1006750 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Raw Sampled: 08/17/2010 06:30
 1006750-01 (Water)

Wet Chemistry

Total Suspended Solids	ND	mg/L		4.0	KDW	08/18/2010 11:45	SM 2540.D.
------------------------	----	------	--	-----	-----	------------------	------------

Metals by EPA 200 Series Methods

Aluminum	0.0794	mg/L	B, N	0.00500	SRR	08/19/2010 14:49	EPA 200.7
Barium	0.0249	mg/L		0.00200	SRR	08/19/2010 14:49	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	08/19/2010 14:49	EPA 200.7
Boron	0.0108	mg/L		0.00100	SRR	08/19/2010 14:49	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	08/19/2010 14:49	EPA 200.7
Chromium	ND	mg/L		0.00100	SRR	08/19/2010 14:49	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	08/19/2010 14:49	EPA 200.7
Copper	0.00281	mg/L	B	0.00100	SRR	08/19/2010 14:49	EPA 200.7
Hardness, Total as CaCO3	75.5	mg/L		0.145	SRR	08/19/2010 15:22	EPA 200.7, SM 2340B
Iron	0.0757	mg/L		0.00600	SRR	08/19/2010 14:49	EPA 200.7
Magnesium	4.56	mg/L		0.00500	SRR	08/19/2010 14:49	EPA 200.7
Manganese	0.0264	mg/L		0.00500	SRR	08/19/2010 14:49	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	08/18/2010 13:57	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	08/19/2010 14:49	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	08/19/2010 14:49	EPA 200.7
Silver	ND	mg/L	N	0.00100	SRR	08/19/2010 14:49	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	08/19/2010 14:49	EPA 200.7
Titanium	0.00177	mg/L		0.00100	SRR	08/19/2010 14:49	EPA 200.7
Zinc	0.0308	mg/L	B	0.00200	SRR	08/19/2010 14:49	EPA 200.7

Metals by EPA 200 Series Methods

Antimony	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Arsenic	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Lead	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Selenium	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Thallium	ND	mg/L		0.00100	AM	08/19/2010 12:13	EPA 200.8

Raw Dissolved Sampled: 08/17/2010 06:30
 1006750-02 (Water)

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/23/2010
 Date Received: 8/17/2010
 Cust #: RC120
 PO#:

Workorder: 1006750 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Raw Dissolved Sampled: 08/17/2010 06:30
 1006750-02 (Water)

Metals (Dissolved) by EPA 200 Series Methods

Aluminum	0.0218	mg/L	B	0.00500	SRR	08/19/2010 15:45	EPA 200.7
Barium	0.0239	mg/L		0.00200	SRR	08/19/2010 15:45	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	08/19/2010 15:45	EPA 200.7
Boron	0.0113	mg/L	B	0.00100	SRR	08/19/2010 15:45	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	08/19/2010 15:45	EPA 200.7
Chromium	ND	mg/L		0.00100	SRR	08/19/2010 15:45	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	08/19/2010 15:45	EPA 200.7
Copper	0.00195	mg/L		0.00100	SRR	08/19/2010 15:45	EPA 200.7
Iron	ND	mg/L		0.00600	SRR	08/19/2010 15:45	EPA 200.7
Magnesium	4.50	mg/L	B	0.00500	SRR	08/19/2010 15:45	EPA 200.7
Manganese	ND	mg/L		0.00500	SRR	08/19/2010 15:45	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	08/18/2010 15:16	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	08/19/2010 15:45	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	08/19/2010 15:45	EPA 200.7
SILICA (SiO2)	5.01	mg/L		0.0107	SRR	08/19/2010 15:45	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	08/19/2010 15:45	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	08/19/2010 15:45	EPA 200.7
Titanium	ND	mg/L		0.00100	SRR	08/19/2010 15:45	EPA 200.7
Zinc	0.0243	mg/L	B	0.00200	SRR	08/19/2010 15:45	EPA 200.7

Metals (Dissolved) by EPA 200 Series Methods

Antimony	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Arsenic	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Lead	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Selenium	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Thallium	ND	mg/L		0.00100	AM	08/19/2010 12:13	EPA 200.8

Finished Sampled: 08/17/2010 06:30
 1006750-03 (Water)

Wet Chemistry

Total Suspended Solids	ND	mg/L		4.0	KDW	08/18/2010 11:45	SM 2540.D.
------------------------	----	------	--	-----	-----	------------------	------------

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/23/2010
 Date Received: 8/17/2010
 Cust #: RC120
 PO#:

Workorder: 1006750 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Finished Sampled: 08/17/2010 06:30
 1006750-03 (Water)

Metals by EPA 200 Series Methods

Aluminum	0.0745	mg/L	B, N	0.00500	SRR	08/19/2010 15:39	EPA 200.7
Barium	0.0241	mg/L		0.00200	SRR	08/19/2010 15:39	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	08/19/2010 15:39	EPA 200.7
Boron	0.0115	mg/L		0.00100	SRR	08/19/2010 15:39	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	08/19/2010 15:39	EPA 200.7
Chromium	ND	mg/L		0.00100	SRR	08/19/2010 15:39	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	08/19/2010 15:39	EPA 200.7
Copper	0.00442	mg/L	B	0.00100	SRR	08/19/2010 15:39	EPA 200.7
Hardness, Total as CaCO3	74.8	mg/L		0.145	SRR	08/20/2010 10:49	EPA 200.7, SM 2340B
Iron	ND	mg/L		0.00600	SRR	08/19/2010 15:39	EPA 200.7
Magnesium	4.59	mg/L		0.00500	SRR	08/19/2010 15:39	EPA 200.7
Manganese	ND	mg/L		0.00500	SRR	08/19/2010 15:39	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	08/18/2010 14:09	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	08/19/2010 15:39	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	08/19/2010 15:39	EPA 200.7
Silver	ND	mg/L	J+, N	0.00100	SRR	08/19/2010 15:39	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	08/19/2010 15:39	EPA 200.7
Titanium	ND	mg/L		0.00100	SRR	08/19/2010 15:39	EPA 200.7
Zinc	0.00927	mg/L	B	0.00200	SRR	08/19/2010 15:39	EPA 200.7

Metals by EPA 200 Series Methods

Antimony	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Arsenic	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Lead	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Selenium	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Thallium	ND	mg/L		0.00100	AM	08/19/2010 12:13	EPA 200.8

Finished Dissolved Sampled: 08/17/2010 06:30
 1006750-04 (Water)

Metals (Dissolved) by EPA 200 Series Methods

Aluminum	0.0843	mg/L	B	0.00500	SRR	08/19/2010 15:51	EPA 200.7
----------	--------	------	---	---------	-----	------------------	-----------

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/23/2010
 Date Received: 8/17/2010
 Cust #: RC120
 PO#:

Workorder: 1006750 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Finished Dissolved Sampled: 08/17/2010 06:30
 1006750-04 (Water)

Metals (Dissolved) by EPA 200 Series Methods

Barium	0.0244	mg/L		0.00200	SRR	08/19/2010 15:51	EPA 200.7
Beryllium	ND	mg/L		0.00100	SRR	08/19/2010 15:51	EPA 200.7
Boron	0.0119	mg/L	B	0.00100	SRR	08/19/2010 15:51	EPA 200.7
Cadmium	ND	mg/L		0.00100	SRR	08/19/2010 15:51	EPA 200.7
Chromium	ND	mg/L		0.00100	SRR	08/19/2010 15:51	EPA 200.7
Cobalt	ND	mg/L		0.00100	SRR	08/19/2010 15:51	EPA 200.7
Copper	0.00434	mg/L		0.00100	SRR	08/19/2010 15:51	EPA 200.7
Iron	ND	mg/L		0.00600	SRR	08/19/2010 15:51	EPA 200.7
Magnesium	4.57	mg/L	B	0.00500	SRR	08/19/2010 15:51	EPA 200.7
Manganese	ND	mg/L		0.00500	SRR	08/19/2010 15:51	EPA 200.7
Mercury	ND	mg/L		0.000200	SRR	08/18/2010 15:20	EPA 245.1
Molybdenum	ND	mg/L		0.00100	SRR	08/19/2010 15:51	EPA 200.7
Nickel	ND	mg/L		0.00100	SRR	08/19/2010 15:51	EPA 200.7
SILICA (SiO2)	5.20	mg/L		0.0107	SRR	08/19/2010 15:51	EPA 200.7
Silver	ND	mg/L		0.00100	SRR	08/19/2010 15:51	EPA 200.7
Tin	ND	mg/L		0.00100	SRR	08/19/2010 15:51	EPA 200.7
Titanium	ND	mg/L		0.00100	SRR	08/19/2010 15:51	EPA 200.7
Zinc	0.0130	mg/L	B	0.00200	SRR	08/19/2010 15:51	EPA 200.7

Metals (Dissolved) by EPA 200 Series Methods

Antimony	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Arsenic	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Lead	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Selenium	ND	mg/L		0.00500	AM	08/19/2010 12:13	EPA 200.8
Thallium	ND	mg/L		0.00100	AM	08/19/2010 12:13	EPA 200.8

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/23/2010
 Date Received: 8/17/2010
 Cust #: RC120
 PO#:

Workorder: 1006750 Project: Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Certifications

Code	Description	Number	Expires
EPA	Environmental Protection Agency	TN00020	
IN_DW	Indiana State Department of Health	C-TN-03	04/30/2011
KY_DW	Commonwealth of Kentucky	90067	12/31/2010
NELAP	Florida Department of Health	E87978	06/30/2010
PA	Commonwealth of Pennsylvania	68-00725 (003)	03/31/2011
TN_DW	State of Tennessee	TN02003	03/12/2011
TN_DW	State of Tennessee	TN02017	04/30/2011
USDA	US Department of Agriculture		11/30/2010
VA_DW	Commonwealth of Virginia	00335	06/30/2010
WV_DW	West Virginia Department of Health and Human Resou	9956 C	12/31/2010

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/23/2010
 Date Received: 8/17/2010
 Cust #: RC120
 PO#:

Workorder: 1006750 **Project:** Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Notes and Definitions

- N Analyte acceptable but matrix spike/matrix spike duplicate outside accepted recovery criteria
- J+ The result is an estimated quantity, but the result may be biased high
- J- The result is an estimated quantity, but the result may be biased low
- B Detected in the associated Method Blank
- DET Analyte DETECTED
- ND Analyte NOT DETECTED at or above the reporting limit
- NR Not Reported
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER





Microbac Laboratories, Inc.
 Knoxville Division
 505 E. Broadway Avenue
 Maryville, TN 37804
 (865) 977-1200 phone
 (865) 984-8616 fax
 http://www.microbac.com
 e-mail: knoxville@microbac.com

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS · WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

Chuck Moore
 City of Kingston
 125 W. Cumberland St.
 Kingston, TN 37763

Date Reported: 8/23/2010
 Date Received: 8/17/2010
 Cust #: RC120
 PO#:

Workorder: 1006750 **Project:** Kingston WTP Raw and Finished Water Samples

Analyte	Result	Units	Qualifier	Reporting Limit	Analyst	Analyzed	Method
---------	--------	-------	-----------	-----------------	---------	----------	--------

Microbac Knoxville

JOE SLOAN, LAB MANAGER

Thank you for your business. We invite your feedback on our level of service to you. Please contact the Laboratory Director, Ashley Morris, at 865-977-1200, the COO, Robert Morgan, at rmorgan@microbac.com or the President, James Nokes, at jnokes@microbac.com with any comments or suggestions.

As regulatory limits change frequently, Microbac advises the recipient of this report to confirm such limits with the appropriate Federal, state, or local authorities before acting in reliance on the regulatory limits provided.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.
 USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

MEMBER



1006750-01 A

Raw

City of Kingston
Water-B-1000ml Plastic HNO3 to pH <2

Sampled: 08/17/2010 06:30



Microbac
MICROBAC LABORATORIES, INC
 KNOXVILLE DIVISION
 505 EAST BROADWAY
 MARYVILLE, TN 37804
 PHONE: (865) 977-1200 FAX: (865) 984-8616

Water System Name: KINGSTON WATER

Report to: Chuck Moore
 Invoice to: James Pinkerton
 Address: 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763
 Address: Same
 Phone: 865-376-7187 Fax: 865-376-1654
 E-mail: kingstonwater@bellsouth.net
 P.O. #:
 Quote #:

PWSID: 0000360
 County: ROANE
 State (of sample origin): TN
 Compliance Monitoring: Yes No
 State Reported: Yes No
 Chlorinated: Yes No

(1) Sample Matrix	Sample Type	# of Containers	ANALYSIS REQUIRED					Sample #
			Total Metals	Dissolved Metals	TSS	Hardness	Dissolved Silica	
DW = Drinking Water								
GW = Ground Water								
(2) Sample Type								
B = Entry Point								
D = Distribution								
Sample Identification	Sample Date	Sample Time						
Raw	8/17/10	0630	DW	4	X	X	X	
Finished	8/17/10	0630	DW	4	X	X	X	

FOR LAB CHECK-IN ONLY
 Temp Rec'd: 2.0 °C
 Properly Preserved: Yes No
 Remarks: pH = 2.2

Collected By: Initial
 Ed Roberts
 Chuck Moore
 Steve McKeethan
 David Banks *D.B.*
 Please Print
 PRIORITY
 Standard
 Next Day
 2-3 Day
 (Surcharge may apply for non-standard TAT)
 Special Instructions / Comments...
 * All are grab samples.
 * Placed immediately on ice.
 * Finish samples are Chlorinated.
 1006750
 Customer #: C120
 Project: C120-COK01
 Job Temp.:

Relinquished By: <i>[Signature]</i>	Date: 8-17-10	Time: 8:10	Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Relinquished By:	Date:	Time:	Received By:	Date:	Time:

Microbac Laboratories Inc.
505 E. Broadway Ave.
Maryville, TN 37804



Main: (865) 977-1200
Fax: (865) 984-8616
www.microbac.com

Cooler Inspection Form

Client Name: Kingston-Altater

Date/Time Received: 6/17/10 8:10

Work Order: 1026750

No. of Samples: 2

Received By: Tiff. Feltner

Checklist Completed By: JMT

Carrier: FedEx() UPS() Client() Field Services() Other(): _____

- After-Hours Receipt? Yes No
- Shipping container in good condition? Yes No Not Present
- Custody seals intact on cooler? Yes No Not Present
- Custody seals intact on samples? Yes No Not Present
- Chain of custody present? Yes No
- Chain of custody includes proper client information? Yes No
- Chain of custody includes proper collection information and signatures? Yes No
- Chain of custody includes dates and times of sample collection? Yes No
- Chain of custody includes proper sample descriptions? Yes No
- Chain of custody agrees with sample labels? Yes No
- Chain of custody identifies proper sample matrix? Yes No
- Chain of custody identifies proper number of samples? Yes No
- Chain of custody includes required analysis? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Samples are in proper containers/bottles? Yes No
- Sample containers are intact? Yes No
- Sufficient sample volume collected for requested analysis? Yes No
- VOA vials for aqueous samples have zero headspace? Yes No Not Present
- Samples received within holding times? Yes No
- Samples received on ice? Yes No
- Sample properly preserved? Yes No

If No, adjusted by? _____ Date/Time: _____

Remarks: _____

ANY "NO" EVALUATION REQUIRES CLIENT NOTIFICATION (excluding After-Hours Receipt).

Comments: _____

